

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-FIELD BLANK			N	011700174-0001	EMSL	03036	1/7/2017	200.8	1/12/2017	17:31	<1.00	1.00	1	N
1-BPLA-18-KITCHEN-KS1-1	Sink	Kitchen	N	011700174-0002	EMSL	03036	1/7/2017	200.8	1/11/2017	23:36	1.33	1.00	1	N
2-BPLA-47-KITCHEN-KS3-1	Sink	Kitchen	N	011700174-0003	EMSL	03036	1/7/2017	200.8	1/11/2017	23:38	<1.00	1.00	1	N
3-BPLA-54-KITCHEN-KS4-1	Sink	Kitchen	N	011700174-0004	EMSL	03036	1/7/2017	200.8	1/11/2017	23:39	1.23	1.00	1	N
4-BPLA-55-KITCHEN-TS35-1	Sink	Kitchen	N	011700174-0005	EMSL	03036	1/7/2017	200.8	1/11/2017	23:40	1.08	1.00	1	N
5-BPLA-3-MEN-TS2-1	Sink	Mens' Restroom	N	011700174-0006	EMSL	03036	1/7/2017	200.8	1/11/2017	23:40	1.74	1.00	1	N
6-BPLA-4-WOMEN-TS3-1	Sink	Womens' Restroom	N	011700174-0007	EMSL	03036	1/7/2017	200.8	1/11/2017	23:43	1.11	1.00	1	N
8-BPLA-20-CLASS-CS3-1	Sink	Classroom	N	011700174-0009	EMSL	03036	1/7/2017	200.8	1/11/2017	23:43	1.28	1.00	1	N
9-BPLA-14-FACULTY-CS1-1	Sink	Faculty Lounge	N	011700174-0010	EMSL	03036	1/7/2017	200.8	1/11/2017	23:44	3.65	1.00	1	N
10-BPLA-10-NURSE-TS10-1	Sink	Nurse's Restroom	N	011700174-0011	EMSL	03036	1/7/2017	200.8	1/11/2017	23:45	3.56	1.00	1	N
11-BPLA-22-WOMEN-TS11-1	Sink	Womens' Restroom	N	011700174-0012	EMSL	03036	1/7/2017	200.8	1/11/2017	23:45	8.91	1.00	1	N
12-BPLA-8-MEN-TS6-1	Sink	Mens' Restroom	N	011700174-0013	EMSL	03036	1/7/2017	200.8	1/11/2017	20:28	<1.00	1.00	1	N
13-BPLA-9-WOMEN-TS7-1	Sink	Womens' Restroom	N	011700174-0014	EMSL	03036	1/7/2017	200.8	1/11/2017	20:30	2.22	1.00	1	N
14-BPLA-10-WOMEN-TS8-1	Sink	Womens' Restroom	N	011700174-0015	EMSL	03036	1/7/2017	200.8	1/11/2017	20:30	1.77	1.00	1	N
15-BPLA-13-TOILET-TS9-1	Sink	Restroom	N	011700174-0016	EMSL	03036	1/7/2017	200.8	1/11/2017	20:31	2.49	1.00	1	N
16-BPLA-27-WOMEN-TS16-1	Sink	Womens' Restroom	N	011700174-0017	EMSL	03036	1/7/2017	200.8	1/11/2017	20:32	1.62	1.00	1	N
17-BPLA-22-WOMEN-TS12-1	Sink	Womens' Restroom	N	011700174-0018	EMSL	03036	1/7/2017	200.8	1/11/2017	20:32	2.43	1.00	1	N
18-BPLA-23-MEN-TS13-1	Sink	Mens' Restroom	N	011700174-0019	EMSL	03036	1/7/2017	200.8	1/11/2017	20:35	2.98	1.00	1	N
19-BPLA-24-MEN-TS14-1	Sink	Mens' Restroom	N	011700174-0020	EMSL	03036	1/7/2017	200.8	1/11/2017	20:36	2.50	1.00	1	N
20-BPLA-26-WOMEN-TS15-1	Sink	Womens' Restroom	N	011700174-0021	EMSL	03036	1/7/2017	200.8	1/11/2017	20:37	1.21	1.00	1	N
21-BPLA-55-WOMEN-TS35-1	Sink	Womens' Restroom	N	011700174-0022	EMSL	03036	1/7/2017	200.8	1/11/2017	20:37	1.14	1.00	1	N
22-BPLA-28-MEN-TS17-1	Sink	Mens' Restroom	N	011700174-0023	EMSL	03036	1/7/2017	200.8	1/11/2017	20:38	8.14	1.00	1	N
23-BPLA-29-MEN-TS18-1	Sink	Mens' Restroom	N	011700174-0024	EMSL	03036	1/7/2017	200.8	1/11/2017	20:40	2.58	1.00	1	N
24-BPLA-57-NURSE-CS5-1	Sink	Nurse's Office	N	011700174-0025	EMSL	03036	1/7/2017	200.8	1/11/2017	20:41	3.38	1.00	1	N
25-BPLA-31-TOILET-TS19-1	Sink	Restroom	N	011700174-0026	EMSL	03036	1/7/2017	200.8	1/11/2017	20:42	4.08	1.00	1	N
26-BPLA-32-TOILET-TS20-1	Sink	Restroom	N	011700174-0027	EMSL	03036	1/7/2017	200.8	1/11/2017	20:44	1.32	1.00	1	N
27-BPLA-33-TOILET-TS21-1	Sink	Restroom	N	011700174-0028	EMSL	03036	1/7/2017	200.8	1/11/2017	20:45	1.04	1.00	1	N
28-BPLA-34-TOILET-TS22-1	Sink	Restroom	N	011700174-0029	EMSL	03036	1/7/2017	200.8	1/11/2017	20:45	<1.00	1.00	1	N
29-BPLA-35-TOILET-TS23-1	Sink	Restroom	N	011700174-0030	EMSL	03036	1/7/2017	200.8	1/11/2017	20:46	<1.00	1.00	1	N
30-BPLA-36-TOILET-TS24-1	Sink	Restroom	N	011700174-0031	EMSL	03036	1/7/2017	200.8	1/11/2017	20:47	10.7	1.00	1	N
31-BPLA-37-TOILET-TS25-1	Sink	Restroom	N	011700174-0032	EMSL	03036	1/7/2017	200.8	1/11/2017	20:47	11.8	1.00	1	N
32-BPLA-39-TOILET-TS26-1	Sink	Restroom	N	011700174-0033	EMSL	03036	1/7/2017	200.8	1/11/2017	20:49	26.8	1.00	1	N
33-BPLA-40-TOILET-TS27-1	Sink	Restroom	N	011700174-0034	EMSL	03036	1/7/2017	200.8	1/11/2017	20:53	130	5.00	5	N
34-BPLA-41-TOILET-TS28-1	Sink	Restroom	N	011700174-0035	EMSL	03036	1/7/2017	200.8	1/11/2017	20:54	4.21	1.00	1	N
35-BPLA-43-WOMEN-TS30-1	Sink	Womens' Restroom	N	011700174-0036	EMSL	03036	1/7/2017	200.8	1/11/2017	20:54	4.42	1.00	1	N
36-BPLA-58-SCIENCE-LS1-1	Sink	Laboratory	N	011700174-0037	EMSL	03036	1/7/2017	200.8	1/11/2017	20:55	9.62	1.00	1	N

37-BPLA-59-SCIENCE-LS15-1	Sink	Laboratory	N	011700174-0038	EMSL	03036	1/7/2017	200.8	1/11/2017	20:56	5.02	1.00	1 N
38-BPLA-60-SCIENCE-LS16-1	Sink	Laboratory	N	011700174-0039	EMSL	03036	1/7/2017	200.8	1/11/2017	20:56	4.52	1.00	1 N
39-BPLA-61-SCIENCE-LS17-1	Sink	Laboratory	N	011700174-0040	EMSL	03036	1/7/2017	200.8	1/11/2017	20:57	3.54	1.00	1 N
40-BPLA-62-SCIENCE-LS18-1	Sink	Laboratory	N	011700174-0041	EMSL	03036	1/7/2017	200.8	1/11/2017	20:58	2.22	1.00	1 N
41-BPLA-63-SCIENCE-LS19-1	Sink	Laboratory	N	011700174-0042	EMSL	03036	1/7/2017	200.8	1/11/2017	20:59	7.36	1.00	1 N
42-BPLA-64-SCIENCE-LS20-1	Sink	Laboratory	N	011700174-0043	EMSL	03036	1/7/2017	200.8	1/11/2017	21:02	6.00	1.00	1 N
43-BPLA-65-SCIENCE-LS21-1	Sink	Laboratory	N	011700174-0044	EMSL	03036	1/7/2017	200.8	1/11/2017	21:04	27.1	1.00	1 N
44-BPLA-66-SCIENCE-LS22-1	Sink	Laboratory	N	011700174-0045	EMSL	03036	1/7/2017	200.8	1/11/2017	21:05	16.5	1.00	1 N
45-BPLA-67-SCIENCE-LS23-1	Sink	Laboratory	N	011700174-0046	EMSL	03036	1/7/2017	200.8	1/11/2017	21:06	7.19	1.00	1 N
46-BPLA-68-SCIENCE-LS24-1	Sink	Laboratory	N	011700174-0047	EMSL	03036	1/7/2017	200.8	1/11/2017	21:06	13.6	1.00	1 N
47-BPLA-69-SCIENCE-LS25-1	Sink	Laboratory	N	011700174-0048	EMSL	03036	1/7/2017	200.8	1/11/2017	21:07	3.18	1.00	1 N
48-BPLA-70-SCIENCE-LS26-1	Sink	Laboratory	N	011700174-0049	EMSL	03036	1/7/2017	200.8	1/11/2017	21:09	1.52	1.00	1 N
49-BPLA-71-SCIENCE-LS27-1	Sink	Laboratory	N	011700174-0050	EMSL	03036	1/7/2017	200.8	1/11/2017	21:10	10.2	1.00	1 N
50-BPLA-44-WOMEN-TS31-1	Sink	Womens' Restroom	N	011700174-0051	EMSL	03036	1/7/2017	200.8	1/11/2017	21:11	2.87	1.00	1 N
51-BPLA-45-WOMEN-TS32-1	Sink	Womens' Restroom	N	011700174-0052	EMSL	03036	1/7/2017	200.8	1/11/2017	21:11	4.82	1.00	1 N
52-BPLA-46-TOILET-TS33-1	Sink	Restroom	N	011700174-0053	EMSL	03036	1/7/2017	200.8	1/11/2017	21:15	2.94	1.00	1 N
53-BPLA-49-TOILET-TS34-1	Sink	Restroom	N	011700174-0054	EMSL	03036	1/7/2017	200.8	1/11/2017	21:18	1.77	1.00	1 N
54-BPLA-72-TOILET-TS35-1	Sink	Restroom	N	011700174-0055	EMSL	03036	1/7/2017	200.8	1/11/2017	21:19	1.88	1.00	1 N
55-BPLA-73-TOILET-TS41-1	Sink	Restroom	N	011700174-0056	EMSL	03036	1/7/2017	200.8	1/11/2017	21:20	9.44	1.00	1 N
56-BPLA-74-TOILET-TS36-1	Sink	Restroom	N	011700174-0057	EMSL	03036	1/7/2017	200.8	1/11/2017	21:21	2.55	1.00	1 N
57-BPLA-75-BOYS-TS37-1	Sink	Boys' Restroom	N	011700174-0058	EMSL	03036	1/7/2017	200.8	1/11/2017	21:21	5.04	1.00	1 N
58-BPLA-76-BOYS-TS38-1	Sink	Boys' Restroom	N	011700174-0059	EMSL	03036	1/7/2017	200.8	1/11/2017	21:22	6.21	1.00	1 N
59-BPLA-77-BOYS-TS39-1	Sink	Boys' Restroom	N	011700174-0060	EMSL	03036	1/7/2017	200.8	1/11/2017	21:23	1.59	1.00	1 N
60-BPLA-78-BOYS-TS40-1	Sink	Boys' Restroom	N	011700174-0061	EMSL	03036	1/7/2017	200.8	1/11/2017	21:23	<1.00	1.00	1 N
61-BPLA-79-CLASS-CS6-1	Sink	Classroom	N	011700174-0062	EMSL	03036	1/7/2017	200.8	1/11/2017	21:24	25.4	1.00	1 N