

Field ID	TYPE	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
1-BRIM-5-LIB-WORKROOM-CS1-1	Sink	Library	N	011608919-0002	EMSL	03036	12/22/2016	200.8	1/3/2017	16:09	77.0	1.00	1	N
20-BRIM-21-PREP RM-LS3-1	Sink	Prep Rm	N	011608919-0021	EMSL	03036	12/22/2016	200.8	1/4/2017	21:30	26.2	1.00	1	N
22-BRIM-25-BIO LAB-LS5-1	Sink	Bio Lab	N	011608919-0023	EMSL	03036	12/22/2016	200.8	1/3/2017	22:24	244	10.0	10	N
23-BRIM-23-BIO LAB-LS6-1	Sink	Bio Lab	N	011608919-0024	EMSL	03036	12/22/2016	200.8	1/4/2017	21:31	20.9	1.00	1	N
24-BRIM-26-PHY LAB-LS7-1	Sink	Phys Lab	N	011608919-0025	EMSL	03036	12/22/2016	200.8	1/4/2017	21:32	65.8	1.00	1	N
28-BRIM-31-CHEM LAB-LS11-1	Sink	Chem Lab	N	011608919-0029	EMSL	03036	12/22/2016	200.8	1/4/2017	21:37	18.0	1.00	1	N
31-BRIM-35-CHEM LAB-LS14-1	Sink	Chem Lab	N	011608919-0032	EMSL	03036	12/22/2016	200.8	1/4/2017	21:39	51.7	1.00	1	N
10-BRIM-10-WOMENS-TS8-1	Sink	Women's Restroom	N	011608919-0011	EMSL	03036	12/22/2016	200.8	1/3/2017	16:18	1.42	1.00	1	N
11-BRIM-11-WOMENS-TS9-1	Sink	Women's Restroom	N	011608919-0012	EMSL	03036	12/22/2016	200.8	1/3/2017	16:19	1.47	1.00	1	N
12-BRIM-12-MENS-TS10-1	Sink	Men's Restroom	N	011608919-0013	EMSL	03036	12/22/2016	200.8	1/3/2017	16:20	<1.00	1.00	1	N
13-BRIM-13-MENS-TS11-1	Sink	Men's Restroom	N	011608919-0014	EMSL	03036	12/22/2016	200.8	1/3/2017	16:20	<1.00	1.00	1	N
14-BRIM-14-MENS-TS12-1	Sink	Men's Restroom	N	011608919-0015	EMSL	03036	12/22/2016	200.8	1/4/2017	21:23	<1.00	1.00	1	N
15-BRIM-15-MENS-TS13-1	Sink	Men's Restroom	N	011608919-0016	EMSL	03036	12/22/2016	200.8	1/4/2017	21:25	<1.00	1.00	1	N
16-BRIM-16-MENS-TS14-1	Sink	Men's Restroom	N	011608919-0017	EMSL	03036	12/22/2016	200.8	1/4/2017	21:25	<1.00	1.00	1	N
17-BRIM-17-PRIN TOILET-TS15-1	Sink	Principal Toilet	N	011608919-0018	EMSL	03036	12/22/2016	200.8	1/4/2017	21:28	<1.00	1.00	1	N
18-BRIM-18-RESEARCH-LS1-1	Sink	Research Lab	N	011608919-0019	EMSL	03036	12/22/2016	200.8	1/4/2017	21:28	5.54	1.00	1	N
19-BRIM-20-PREP RM-LS2-1	Sink	Prep Rm	N	011608919-0020	EMSL	03036	12/22/2016	200.8	1/4/2017	21:29	9.63	1.00	1	N

21-BRIM-22-BIO LAB-LS4-1	Sink	Bio Lab	N	011608919-0022	EMSL	03036	12/22/2016	200.8	1/4/2017	21:30	2.97	1.00	1	N
25-BRIM-27-PHY LAB-LS8-1	Sink	Phys Lab	N	011608919-0026	EMSL	03036	12/22/2016	200.8	1/4/2017	21:32	7.08	1.00	1	N
26-BRIM-29-CHEM LAB-LS9-1	Sink	Chem Lab	N	011608919-0027	EMSL	03036	12/22/2016	200.8	1/4/2017	21:36	9.17	1.00	1	N
27-BRIM-30-CHEM LAB-LS10-1	Sink	Chem Lab	N	011608919-0028	EMSL	03036	12/22/2016	200.8	1/4/2017	21:37	1.14	1.00	1	N
29-BRIM-32-CHEM LAB-LS12-1	Sink	Chem Lab	N	011608919-0030	EMSL	03036	12/22/2016	200.8	1/4/2017	21:38	4.90	1.00	1	N
2-BRIM-1-MENS-TS1-1	Sink	Men's Restroom	N	011608919-0003	EMSL	03036	12/22/2016	200.8	1/3/2017	16:09	<1.00	1.00	1	N
30-BRIM-33-CHEM LAB-LS13-1	Sink	Chem Lab	N	011608919-0031	EMSL	03036	12/22/2016	200.8	1/4/2017	21:39	4.82	1.00	1	N
32-BRIM-36-KITCHEN-KS1-1	Sink	Kitchen	N	011608919-0033	EMSL	03036	12/22/2016	200.8	1/4/2017	21:40	<1.00	1.00	1	N
33-BRIM-37-KITCHEN-KS2-1	Sink	Kitchen	N	011608919-0034	EMSL	03036	12/22/2016	200.8	1/3/2017	15:21	<1.00	1.00	1	N
34-BRIM-39-KITCHEN-TOILET-TS16-1	Sink	Kitchen Bathroom	N	011608919-0035	EMSL	03036	12/22/2016	200.8	1/3/2017	15:22	1.02	1.00	1	N
35-BRIM-47-KITCHEN-KS3-1	Sink	Kitchen	N	011608919-0036	EMSL	03036	12/22/2016	200.8	1/3/2017	15:25	1.42	1.00	1	N
36-BRIM-48-KITCHEN-KS4-1	Sink	Kitchen	N	011608919-0037	EMSL	03036	12/22/2016	200.8	1/3/2017	15:22	<1.00	1.00	1	N
37-BRIM-40-TEACHERS LOUNGE-CS3-1	Sink	Teacher's Lounge	N	011608919-0038	EMSL	03036	12/22/2016	200.8	1/3/2017	15:25	<1.00	1.00	1	N
38-BRIM-42-MENS-TS17-1	Sink	Men's Restroom	N	011608919-0039	EMSL	03036	12/22/2016	200.8	1/3/2017	15:26	<1.00	1.00	1	N
39-BRIM-43-MENS-TS18-1	Sink	Men's Restroom	N	011608919-0040	EMSL	03036	12/22/2016	200.8	1/3/2017	15:27	<1.00	1.00	1	N
3-BRIM-2-WOMENS-TS2-1	Sink	Women's Restroom	N	011608919-0004	EMSL	03036	12/22/2016	200.8	1/3/2017	16:10	2.01	1.00	1	N
40-BRIM-44-WOMEN-TS19-1	Sink	Women's Restroom	N	011608919-0041	EMSL	03036	12/22/2016	200.8	1/3/2017	15:27	1.29	1.00	1	N
41-BRIM-45-WOMEN-TS20-1	Sink	Women's Restroom	N	011608919-0042	EMSL	03036	12/22/2016	200.8	1/3/2017	15:28	<1.00	1.00	1	N

4-BRIM-46-WOMENS-TS46-1	Sink	Women's Restroom	N	011608919-0005	EMSL	03036	12/22/2016	200.8	1/3/2017	16:11	<1.00	1.00	1	N
5-BRIM-6-NURSE-CS2-1	Sink	Nurse	N	011608919-0006	EMSL	03036	12/22/2016	200.8	1/3/2017	16:13	2.04	1.00	1	N
6-BRIM-4-TOILET-TS4-1	Sink	Restroom	N	011608919-0007	EMSL	03036	12/22/2016	200.8	1/3/2017	16:14	<1.00	1.00	1	N
7-BRIM-7-WOMENS-TS5-1	Sink	Women's Restroom	N	011608919-0008	EMSL	03036	12/22/2016	200.8	1/3/2017	16:16	<1.00	1.00	1	N
8-BRIM-8-WOMENS-TS6-1	Sink	Women's Restroom	N	011608919-0009	EMSL	03036	12/22/2016	200.8	1/3/2017	16:17	1.11	1.00	1	N
9-BRIM-9-WOMENS-TS7-1	Sink	Women's Restroom	N	011608919-0010	EMSL	03036	12/22/2016	200.8	1/3/2017	16:18	<1.00	1.00	1	N
FB-FIELD BLANK			N	011608919-0001	EMSL	03036	12/22/2016	200.8	1/3/2017	16:08	<1.00	1.00	1	N