

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-FIELD BLANK			N	011608740-0001	EMSL	03036	12/16/2016	200.8	12/30/2016	18:00	<1.00	1.00	1	N
1-CPS-6-TOILET-TS2-1	Sink	Restroom	N	011608740-0002	EMSL	03036	12/16/2016	200.8	12/30/2016	18:02	10.1	1.00	1	N
2-CPS-4-CUST CLOSET-SS-1	Slop Sink	Janitors' Closet	N	011608740-0003	EMSL	03036	12/16/2016	200.8	12/30/2016	18:03	<1.00	1.00	1	N
10-CPS-12-CLASSROOM-CS7-1	Sink	Classroom	N	011608740-0011	EMSL	03036	12/16/2016	200.8	12/30/2016	18:08	2.27	1.00	1	N
11-CPS-13-CLASSROOM-CS8-1	Sink	Classroom	N	011608740-0012	EMSL	03036	12/16/2016	200.8	12/30/2016	18:09	1.61	1.00	1	N
12-CPS-14-CLASSROOM-CS9-1	Sink	Classroom	N	011608740-0013	EMSL	03036	12/16/2016	200.8	12/30/2016	18:10	10.1	1.00	1	N
6-CPS-9-KITCHEN-KS2-1	Sink	Kitchen	N	011608740-0007	EMSL	03036	12/16/2016	200.8	12/30/2016	18:06	<1.00	1.00	1	N
7-CPS-8-KITCHEN-KS1-1	Sink	Kitchen	N	011608740-0008	EMSL	03036	12/16/2016	200.8	1/4/2017	12:57	<1.00	1.00	1	N
13-CPS-26-KINDER-CS15-1	Sink	Classroom	N	011608740-0014	EMSL	03036	12/16/2016	200.8	12/30/2016	18:12	<1.00	1.00	1	N
14-CPS-25-KINDER-CS14-1	Sink	Classroom	N	011608740-0015	EMSL	03036	12/16/2016	200.8	12/30/2016	18:15	1.13	1.00	1	N
19-CPS-18-CLASSROOM-CS13-1	Sink	Classroom	N	011608740-0020	EMSL	03036	12/16/2016	200.8	12/30/2016	18:19	<1.00	1.00	1	N
20-CPS-17-CLASSROOM-CS12-1	Sink	Classroom	N	011608740-0021	EMSL	03036	12/16/2016	200.8	12/30/2016	18:19	3.36	1.00	1	N
21-CPS-16-CLASSROOM-CS11-1	Sink	Classroom	N	011608740-0022	EMSL	03036	12/16/2016	200.8	12/30/2016	18:20	13.5	1.00	1	N
22-CPS-15-CLASSROOM-CS10-1	Sink	Classroom	N	011608740-0023	EMSL	03036	12/16/2016	200.8	12/30/2016	18:55	<1.00	1.00	1	N
38-CPS-65-ROOM 8-CS25-1	Sink	Classroom	N	011608740-0039	EMSL	03036	12/16/2016	200.8	12/30/2016	19:12	11.0	1.00	1	N
15-CPS-22-BOYS-TS6-1	Sink	Boys' Restroom	N	011608740-0016	EMSL	03036	12/16/2016	200.8	12/30/2016	18:16	<1.00	1.00	1	N
16-CPS-21-BOYS-TS5-1	Sink	Boys' Restroom	N	011608740-0017	EMSL	03036	12/16/2016	200.8	12/30/2016	18:17	<1.00	1.00	1	N
17-CPS-20-GIRLS-TS4-1	Sink	Girls' Restroom	N	011608740-0018	EMSL	03036	12/16/2016	200.8	12/30/2016	18:17	1.10	1.00	1	N
18-CPS-19-GIRLS-TS3-1	Sink	Girls' Restroom	N	011608740-0019	EMSL	03036	12/16/2016	200.8	12/30/2016	18:18	<1.00	1.00	1	N
3-CPS-2-SP ED CLASS-CS2-1	Sink	Classroom	N	011608740-0004	EMSL	03036	12/16/2016	200.8	12/30/2016	18:03	<1.00	1.00	1	N
45-CPS-73-ROOM 26-CS22-1	Sink	Classroom	N	011608740-0046	EMSL	03036	12/16/2016	200.8	12/30/2016	19:23	1.09	1.00	1	N
4-CPS-1-SP ED CLASS-CS1-1	Sink	Classroom	N	011608740-0005	EMSL	03036	12/16/2016	200.8	1/4/2017	12:57	<1.00	1.00	1	N
53-CPS-72-ROOM 27-CS21-1	Sink	Classroom	N	011608740-0054	EMSL	03036	12/16/2016	200.8	12/30/2016	19:31	<1.00	1.00	1	N
23-CPS-39-BOYS-TS12-1	Sink	Boys' Restroom	N	011608740-0024	EMSL	03036	12/16/2016	200.8	12/30/2016	18:57	<1.00	1.00	1	N
24-CPS-38-BOYS-TS11-1	Sink	Boys' Restroom	N	011608740-0025	EMSL	03036	12/16/2016	200.8	12/30/2016	18:58	<1.00	1.00	1	N
25-CPS-37-BOYS-TS10-1	Sink	Boys' Restroom	N	011608740-0026	EMSL	03036	12/16/2016	200.8	12/30/2016	18:58	<1.00	1.00	1	N
26-CPS-44-GIRLS-TS17-1	Sink	Girls' Restroom	N	011608740-0027	EMSL	03036	12/16/2016	200.8	12/30/2016	18:59	<1.00	1.00	1	N
27-CPS-43-GIRLS-TS16-1	Sink	Girls' Restroom	N	011608740-0028	EMSL	03036	12/16/2016	200.8	12/30/2016	19:00	<1.00	1.00	1	N
28-CPS-42-GIRLS-TS15-1	Sink	Girls' Restroom	N	011608740-0029	EMSL	03036	12/16/2016	200.8	12/30/2016	19:01	<1.00	1.00	1	N
29-CPS-41-GIRLS-TS14-1	Sink	Girls' Restroom	N	011608740-0030	EMSL	03036	12/16/2016	200.8	12/30/2016	19:03	<1.00	1.00	1	N
30-CPS-36-TOILET-TS9-1	Sink	Restroom	N	011608740-0031	EMSL	03036	12/16/2016	200.8	12/30/2016	19:03	1.54	1.00	1	N

31-CPS-35-TOILET-TS8-1	Sink	Restroom	N	011608740-0032	EMSL	03036	12/16/2016	200.8	12/30/2016	19:04	<1.00	1.00	1	N
32-CPS-81-BOYS-TS38-1	Sink	Restroom	N	011608740-0033	EMSL	03036	12/16/2016	200.8	12/30/2016	19:05	<1.00	1.00	1	N
33-CPS-51-BOYS-TS22-1	Sink	Boys' Restroom	N	011608740-0034	EMSL	03036	12/16/2016	200.8	12/30/2016	19:07	<1.00	1.00	1	N
34-CPS-50-BOYS-TS21-1	Sink	Boys' Restroom	N	011608740-0035	EMSL	03036	12/16/2016	200.8	12/30/2016	19:08	<1.00	1.00	1	N
35-CPS-49-GIRLS-TS20-1	Sink	Girls' Restroom	N	011608740-0036	EMSL	03036	12/16/2016	200.8	12/30/2016	19:08	2.06	1.00	1	N
36-CPS-48-GIRLS-TS19-1	Sink	Girls' Restroom	N	011608740-0037	EMSL	03036	12/16/2016	200.8	12/30/2016	19:09	1.88	1.00	1	N
37-CPS-47-GIRLS-TS18-1	Sink	Girls' Restroom	N	011608740-0038	EMSL	03036	12/16/2016	200.8	12/30/2016	19:11	1.21	1.00	1	N
54-CPS-71-ROOM 27-CS20-1	Sink	Classroom	N	011608740-0055	EMSL	03036	12/16/2016	200.8	12/30/2016	19:32	1.16	1.00	1	N
39-CPS-53-TOILET-TS23-1	Sink	Restroom	N	011608740-0040	EMSL	03036	12/16/2016	200.8	12/30/2016	19:13	1.01	1.00	1	N
40-CPS-54-TOILET-TS24-1	Sink	Restroom	N	011608740-0041	EMSL	03036	12/16/2016	200.8	12/30/2016	19:13	<1.00	1.00	1	N
41-CPS-59-BOYS-TS29-1	Sink	Boys' Restroom	N	011608740-0042	EMSL	03036	12/16/2016	200.8	12/30/2016	19:14	<1.00	1.00	1	N
42-CPS-60-BOYS-TS30-1	Sink	Boys' Restroom	N	011608740-0043	EMSL	03036	12/16/2016	200.8	12/30/2016	19:18	1.08	1.00	1	N
43-CPS-56-GIRLS-TS26-1	Sink	Girls' Restroom	N	011608740-0044	EMSL	03036	12/16/2016	200.8	12/30/2016	19:21	1.33	1.00	1	N
44-CPS-57-GIRLS-TS27-1	Sink	Girls' Restroom	N	011608740-0045	EMSL	03036	12/16/2016	200.8	12/30/2016	19:22	1.81	1.00	1	N
55-CPS-70-ROOM 27-CS19-1	Sink	Classroom	N	011608740-0056	EMSL	03036	12/16/2016	200.8	12/30/2016	19:32	<1.00	1.00	1	N
46-CPS-74-BOYS-TS31-1	Sink	Boys' Restroom	N	011608740-0047	EMSL	03036	12/16/2016	200.8	12/30/2016	19:23	<1.00	1.00	1	N
47-CPS-75-BOYS-TS32-1	Sink	Boys' Restroom	N	011608740-0048	EMSL	03036	12/16/2016	200.8	12/30/2016	19:24	<1.00	1.00	1	N
48-CPS-76-BOYS-TS33-1	Sink	Boys' Restroom	N	011608740-0049	EMSL	03036	12/16/2016	200.8	12/30/2016	19:25	<1.00	1.00	1	N
49-CPS-77-GIRLS-TS34-1	Sink	Girls' Restroom	N	011608740-0050	EMSL	03036	12/16/2016	200.8	12/30/2016	19:25	<1.00	1.00	1	N
50-CPS-78-GIRLS-TS35-1	Sink	Girls' Restroom	N	011608740-0051	EMSL	03036	12/16/2016	200.8	12/30/2016	19:26	<1.00	1.00	1	N
51-CPS-79-GIRLS-TS36-1	Sink	Girls' Restroom	N	011608740-0052	EMSL	03036	12/16/2016	200.8	12/30/2016	19:28	<1.00	1.00	1	N
52-CPS-82-GIRLS-TS39-1	Sink	Girls' Restroom	N	011608740-0053	EMSL	03036	12/16/2016	200.8	12/30/2016	19:29	<1.00	1.00	1	N
56-CPS-69-ROOM 27-CS18-1	Sink	Classroom	N	011608740-0057	EMSL	03036	12/16/2016	200.8	12/30/2016	19:33	6.36	1.00	1	N
57-CPS-67-ROOM 27-CS16-1	Sink	Classroom	N	011608740-0058	EMSL	03036	12/16/2016	200.8	12/30/2016	19:34	16.3	1.00	1	N
5-CPS-7-NURSE-CS4-1	Sink	Classroom	N	011608740-0006	EMSL	03036	12/16/2016	200.8	12/30/2016	18:05	<1.00	1.00	1	N
60-CPS-3-CLINIC-CS3-1	Sink	Classroom	N	011608740-0061	EMSL	03036	12/16/2016	200.8	12/30/2016	19:38	2.07	1.00	1	N
8-CPS-10-MPR-CS5-1	Sink	Classroom	N	011608740-0009	EMSL	03036	12/16/2016	200.8	12/30/2016	18:07	<1.00	1.00	1	N
58-CPS-24-PRINC TOILET-TS7-1	Sink	Principal Restroom	N	011608740-0059	EMSL	03036	12/16/2016	200.8	12/30/2016	19:35	9.13	1.00	1	N
59-CPS-84-OFFICE-TS37-1	Sink	Office Restroom	N	011608740-0060	EMSL	03036	12/16/2016	200.8	12/30/2016	19:37	<1.00	1.00	1	N
9-CPS-11-CLASSROOM-CS6-1	Sink	Classroom	N	011608740-0010	EMSL	03036	12/16/2016	200.8	12/30/2016	18:07	<1.00	1.00	1	N