

													Lab			
Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	
FB-FIELD BLANK			N	011608669-0001	EMSL	03036	12/15/2016	04:31	200.8	12/30/2016	2:51	<1.00	1.00		1 N	
1-CES-1-MECH-CS1-1	Sink	Shop Classroom	N	011608669-0002	EMSL	03036	12/15/2016	04:37	200.8	12/30/2016	2:54	42.4	1.00		1 N	
2-CES-2-KITCHEN-KS1-1	Sink	Kitchen	N	011608669-0003	EMSL	03036	12/15/2016	04:42	200.8	12/30/2016	2:55	<1.00	1.00		1 N	
3-CES-3-KITCHEN-KS2-1	Sink	Kitchen	N	011608669-0004	EMSL	03036	12/15/2016	04:44	200.8	12/30/2016	2:55	1.31	1.00		1 N	
4-CES-4-ROOM 4-CS2-1	Sink	Classroom	N	011608669-0005	EMSL	03036	12/15/2016	04:53	200.8	12/30/2016	2:56	<1.00	1.00		1 N	
5-CES-5-ROOM 3-CS3-1	Sink	Classroom	N	011608669-0006	EMSL	03036	12/15/2016	04:56	200.8	12/30/2016	2:57	<1.00	1.00		1 N	
6-CES-6-ROOM 5-CS4-1	Sink	Classroom	N	011608669-0007	EMSL	03036	12/15/2016	04:59	200.8	12/30/2016	2:57	2.41	1.00		1 N	
7-CES-7-TOILET-TS1-1	Sink	Restroom	N	011608669-0008	EMSL	03036	12/15/2016	05:02	200.8	12/30/2016	2:58	28.3	1.00		1 N	
8-CES-9-GIRLS-TS2-1	Sink	Girls' Restroom	N	011608669-0009	EMSL	03036	12/15/2016	05:05	200.8	12/30/2016	2:59	11.8	1.00		1 N	
9-CES-10-GIRLS-TS3-1	Sink	Girls' Restroom	N	011608669-0010	EMSL	03036	12/15/2016	05:07	200.8	12/30/2016	3:00	1.74	1.00		1 N	
10-CES-11-GIRLS-TS4-1	Sink	Girls' Restroom	N	011608669-0011	EMSL	03036	12/15/2016	05:09	200.8	12/30/2016	3:03	2.36	1.00		1 N	
11-CES-12-GIRLS-TS5-1	Sink	Girls' Restroom	N	011608669-0012	EMSL	03036	12/15/2016	05:12	200.8	12/30/2016	3:05	2.63	1.00		1 N	
12-CES-13-ROOM 19-CS5-1	Sink	Classroom	N	011608669-0013	EMSL	03036	12/15/2016	05:15	200.8	12/30/2016	3:06	16.9	1.00		1 N	
13-CES-14-NURSE-CS6-1	Sink	Nurse's Office	N	011608669-0014	EMSL	03036	12/15/2016	05:18	200.8	12/30/2016	3:07	2.01	1.00		1 N	
14-CES-15-ROOM 8-CS7-1	Sink	Classroom	N	011608669-0015	EMSL	03036	12/15/2016	05:27	200.8	12/30/2016	3:07	1.51	1.00		1 N	
15-CES-16-TOILET-TS6-1	Sink	Restroom	N	011608669-0016	EMSL	03036	12/15/2016	05:27	200.8	12/30/2016	3:08	1.63	1.00		1 N	
16-CES-17-ROOM 16-CS8-1	Sink	Classroom	N	011608669-0017	EMSL	03036	12/15/2016	05:31	200.8	12/30/2016	3:10	2.35	1.00		1 N	
17-CES-18-ROOM 13-CS9-1	Sink	Classroom	N	011608669-0018	EMSL	03036	12/15/2016	05:34	200.8	12/30/2016	3:11	12.5	1.00		1 N	
18-CES-19-BOYS-TS7-1	Sink	Boys' Restroom	N	011608669-0019	EMSL	03036	12/15/2016	05:38	200.8	12/30/2016	3:11	1.75	1.00		1 N	
19-CES-20-BOYS-TS8-1	Sink	Boys' Restroom	N	011608669-0020	EMSL	03036	12/15/2016	05:40	200.8	12/30/2016	3:12	2.36	1.00		1 N	
20-CES-21-BOYS-TS9-1	Sink	Boys' Restroom	N	011608669-0021	EMSL	03036	12/15/2016	05:43	200.8	12/30/2016	3:13	1.25	1.00		1 N	
21-CES-23-TOILET-TS10-1	Sink	Restroom	N	011608669-0022	EMSL	03036	12/15/2016	05:46	200.8	12/30/2016	3:15	5.12	1.00		1 N	
22-CES-24-NURSE-TS11-1	Sink	Restroom	N	011608669-0023	EMSL	03036	12/15/2016	05:48	200.8	12/30/2016	3:16	<1.00	1.00		1 N	
23-CES-25-GIRLS-TS12-1	Sink	Girls' Restroom	N	011608669-0024	EMSL	03036	12/15/2016	05:52	200.8	12/30/2016	3:16	2.41	1.00		1 N	
24-CES-26-GIRLS-TS13-1	Sink	Girls' Restroom	N	011608669-0025	EMSL	03036	12/15/2016	05:54	200.8	12/30/2016	3:18	4.62	1.00		1 N	
25-CES-27-GIRLS-TS14-1	Sink	Girls' Restroom	N	011608669-0026	EMSL	03036	12/15/2016	05:56	200.8	12/30/2016	3:19	3.01	1.00		1 N	
26-CES-28-GIRLS-TS15-1	Sink	Girls' Restroom	N	011608669-0027	EMSL	03036	12/15/2016	05:58	200.8	12/30/2016	3:20	2.84	1.00		1 N	
27-CES-30-TOILET-TS16-1	Sink	Restroom	N	011608669-0028	EMSL	03036	12/15/2016	06:02	200.8	12/30/2016	3:21	3.61	1.00		1 N	
28-CES-31-TOILET-TS17-1	Sink	Restroom	N	011608669-0029	EMSL	03036	12/15/2016	06:04	200.8	12/30/2016	3:21	2.33	1.00		1 N	
29-CES-32-ROOM 12-CS10-1	Sink	Classroom	N	011608669-0030	EMSL	03036	12/15/2016	06:07	200.8	12/30/2016	3:22	21.9	1.00		1 N	
30-CES-33-BOYS-TS18-1	Sink	Boys' Restroom	N	011608669-0031	EMSL	03036	12/15/2016	06:10	200.8	12/30/2016	3:24	6.23	1.00		1 N	
31-CES-34-BOYS-TS19-1	Sink	Boys' Restroom	N	011608669-0032	EMSL	03036	12/15/2016	06:12	200.8	12/30/2016	3:28	8.03	1.00		1 N	
32-CES-35-BOYS-TS20-1	Sink	Boys' Restroom	N	011608669-0033	EMSL	03036	12/15/2016	06:14	200.8	12/30/2016	3:29	7.02	1.00		1 N	
33-CES-36-GIRLS-TS21-1	Sink	Girls' Restroom	N	011608669-0034	EMSL	03036	12/15/2016	06:21	200.8	12/30/2016	3:30	1.56	1.00		1 N	
34-CES-37-GIRLS-TS22-1	Sink	Girls' Restroom	N	011608669-0035	EMSL	03036	12/15/2016	06:23	200.8	12/30/2016	3:30	1.75	1.00		1 N	
35-CES-38-GIRLS-TS23-1	Sink	Girls' Restroom	N	011608669-0036	EMSL	03036	12/15/2016	06:26	200.8	12/30/2016	3:31	1.91	1.00		1 N	

36-CES-39-GIRLS-TS24-1	Sink	Girls' Restroom	N	011608669-0037	EMSL	03036	12/15/2016 06:28	200.8	12/30/2016	3:32	2.41	1.00	1	N
37-CES-41-TOILET-TS25-1	Sink	Restroom	N	011608669-0038	EMSL	03036	12/15/2016 06:33	200.8	12/30/2016	3:32	2.17	1.00	1	N
38-CES-42-TOILET-TS26-1	Sink	Restroom	N	011608669-0039	EMSL	03036	12/15/2016 06:35	200.8	12/30/2016	3:33	2.29	1.00	1	N
39-CES-43-BOYS-TS27-1	Sink	Boys' Restroom	N	011608669-0040	EMSL	03036	12/15/2016 06:37	200.8	12/30/2016	3:34	3.22	1.00	1	N
40-CES-44-BOYS-TS28-1	Sink	Boys' Restroom	N	011608669-0041	EMSL	03036	12/15/2016 06:39	200.8	12/30/2016	3:37	3.09	1.00	1	N
41-CES-45-BOYS-TS29-1	Sink	Boys' Restroom	N	011608669-0042	EMSL	03036	12/15/2016 06:41	200.8	12/30/2016	3:39	3.89	1.00	1	N
42-CES-46-TOILET-TS30-1	Sink	Restroom	N	011608669-0043	EMSL	03036	12/15/2016 06:44	200.8	12/30/2016	3:40	1.18	1.00	1	N
43-CES-48-ROOM 11-CS11-1	Sink	Restroom	N	011608669-0044	EMSL	03036	12/15/2016 06:47	200.8	12/30/2016	3:41	49.6	1.00	1	N