

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-FIELD BLANK			N	011608780-0001	EMSL	03036	12/19/2016	04:07	200.8	1/3/2017	13:49	<1.00	1.00	1	N
1-CRS-5-NURSE-CS2-1	Sink	Nurse's Office	N	011608780-0002	EMSL	03036	12/19/2016	04:12	200.8	1/3/2017	13:51	<1.00	1.00	1	N
2-CRS-3-NURSE-TS2-1	Sink	Nurse's Restroom	N	011608780-0003	EMSL	03036	12/19/2016	04:15	200.8	1/3/2017	13:52	1.23	1.00	1	N
3-CRS-2-TOILET-TS1-1	Sink	Restroom	N	011608780-0004	EMSL	03036	12/19/2016	04:19	200.8	1/3/2017	13:53	2.30	1.00	1	N
4-CRS-1-LIBRARY-CS1-1	Sink	Library	N	011608780-0005	EMSL	03036	12/19/2016	04:22	200.8	1/3/2017	13:53	<1.00	1.00	1	N
5-CRS-4-TOILET-TS3-1	Sink	Restroom	N	011608780-0006	EMSL	03036	12/19/2016	04:26	200.8	1/3/2017	13:54	2.81	1.00	1	N
6-CRS-6-TOILET-TS4-1	Sink	Restroom	N	011608780-0007	EMSL	03036	12/19/2016	04:28	200.8	1/3/2017	13:56	4.88	1.00	1	N
7-CRS-7-TOILET-TS5-1	Sink	Restroom	N	011608780-0008	EMSL	03036	12/19/2016	04:30	200.8	1/3/2017	13:57	1.85	1.00	1	N
8-CRS-8-BOYS-TS6-1	Sink	Boys' Restroom	N	011608780-0009	EMSL	03036	12/19/2016	04:33	200.8	1/3/2017	13:58	<1.00	1.00	1	N
9-CRS-9-BOYS-TS7-1	Sink	Boys' Restroom	N	011608780-0010	EMSL	03036	12/19/2016	04:34	200.8	1/3/2017	13:58	<1.00	1.00	1	N
10-CRS-10-BOYS-TS8-1	Sink	Boys' Restroom	N	011608780-0011	EMSL	03036	12/19/2016	04:35	200.8	1/3/2017	13:59	<1.00	1.00	1	N
11-CRS-11-BOYS-TS9-1	Sink	Boys' Restroom	N	011608780-0012	EMSL	03036	12/19/2016	04:36	200.8	1/3/2017	14:01	<1.00	1.00	1	N
12-CRS-13-GIRLS-TS10	Sink	Girls' Restroom	N	011608780-0013	EMSL	03036	12/19/2016	04:41	200.8	1/3/2017	14:02	<1.00	1.00	1	N
13-CRS-14-GIRLS-TS11-1	Sink	Girls' Restroom	N	011608780-0014	EMSL	03036	12/19/2016	04:42	200.8	1/3/2017	14:02	<1.00	1.00	1	N
14-CRS-15-GIRLS-TS12-1	Sink	Girls' Restroom	N	011608780-0015	EMSL	03036	12/19/2016	04:43	200.8	1/3/2017	14:04	3.49	1.00	1	N
15-CRS-16-GIRLS-TS13-1	Sink	Girls' Restroom	N	011608780-0016	EMSL	03036	12/19/2016	04:44	200.8	1/3/2017	14:05	<1.00	1.00	1	N
16-CRS-17-TOILET-TS14-1	Sink	Restroom	N	011608780-0017	EMSL	03036	12/19/2016	04:51	200.8	1/3/2017	14:06	<1.00	1.00	1	N
17-CRS-18-TOILET-TS15-1	Sink	Restroom	N	011608780-0018	EMSL	03036	12/19/2016	04:53	200.8	1/3/2017	14:06	<1.00	1.00	1	N
18-CRS-19-TOILET-TS16-1	Sink	Restroom	N	011608780-0019	EMSL	03036	12/19/2016	04:57	200.8	1/3/2017	14:07	<1.00	1.00	1	N
19-CRS-20-KITCHEN-KS1-1	Sink	Kitchen	N	011608780-0020	EMSL	03036	12/19/2016	05:00	200.8	1/3/2017	14:08	<1.00	1.00	1	N
20-CRS-21-KITCHEN-KS2-1	Sink	Kitchen	N	011608780-0021	EMSL	03036	12/19/2016	05:01	200.8	1/3/2017	14:15	<1.00	1.00	1	N

21-CRS-22-BOYS-TS17-1	Sink	Boys' Restroom	N	011608780-0022	EMSL	03036	12/19/2016	05:08	200.8	1/3/2017	14:17	<1.00	1.00	1	N
22-CRS-23-BOYS-TS18-1	Sink	Boys' Restroom	N	011608780-0023	EMSL	03036	12/19/2016	05:09	200.8	1/3/2017	14:18	<1.00	1.00	1	N
23-CRS-24-BOYS-TS19-1	Sink	Boys' Restroom	N	011608780-0024	EMSL	03036	12/19/2016	05:10	200.8	1/3/2017	14:18	<1.00	1.00	1	N
24-CRS-25-BOYS-TS20-1	Sink	Boys' Restroom	N	011608780-0025	EMSL	03036	12/19/2016	05:11	200.8	1/3/2017	14:19	<1.00	1.00	1	N
25-CRS-27-GIRLS-TS21-1	Sink	Girls' Restroom	N	011608780-0026	EMSL	03036	12/19/2016	05:16	200.8	1/3/2017	14:20	<1.00	1.00	1	N
26-CRS-28-GIRLS-TS22-1	Sink	Girls' Restroom	N	011608780-0027	EMSL	03036	12/19/2016	05:17	200.8	1/3/2017	14:22	<1.00	1.00	1	N
27-CRS-29-GIRLS-TS23-1	Sink	Girls' Restroom	N	011608780-0028	EMSL	03036	12/19/2016	05:18	200.8	1/3/2017	14:22	<1.00	1.00	1	N
28-CRS-30-GIRLS-TS24-1	Sink	Girls' Restroom	N	011608780-0029	EMSL	03036	12/19/2016	05:20	200.8	1/3/2017	14:23	<1.00	1.00	1	N
29-CRS-31-CLASS-CS3-1	Sink	Classroom	N	011608780-0030	EMSL	03036	12/19/2016	05:26	200.8	1/3/2017	14:24	2.55	1.00	1	N
30-CRS-32-SCIENCE-LS1-1	Sink	Laboratory	N	011608780-0031	EMSL	03036	12/19/2016	05:28	200.8	1/3/2017	14:25	1.62	1.00	1	N
31-CRS-33-SCIENCE-LS2-1	Sink	Laboratory	N	011608780-0032	EMSL	03036	12/19/2016	05:29	200.8	1/3/2017	14:27	3.86	1.00	1	N
32-CRS-35-BOYS-TS25-1	Sink	Boys' Restroom	N	011608780-0033	EMSL	03036	12/19/2016	05:35	200.8	1/3/2017	14:27	<1.00	1.00	1	N
33-CRS-36-BOYS-TS26-1	Sink	Boys' Restroom	N	011608780-0034	EMSL	03036	12/19/2016	05:36	200.8	1/3/2017	14:28	2.12	1.00	1	N
34-CRS-37-BOYS-TS27-1	Sink	Boys' Restroom	N	011608780-0035	EMSL	03036	12/19/2016	05:37	200.8	1/3/2017	14:30	<1.00	1.00	1	N
35-CRS-38-BOYS-TS28-1	Sink	Boys' Restroom	N	011608780-0036	EMSL	03036	12/19/2016	05:38	200.8	1/3/2017	14:31	<1.00	1.00	1	N
36-CRS-40-GIRLS-TS29-1	Sink	Girls' Restroom	N	011608780-0037	EMSL	03036	12/19/2016	05:43	200.8	1/3/2017	14:31	<1.00	1.00	1	N
37-CRS-41-GIRLS-TS30-1	Sink	Girls' Restroom	N	011608780-0038	EMSL	03036	12/19/2016	05:44	200.8	1/3/2017	14:32	<1.00	1.00	1	N
38-CRS-42-GIRLS-TS31-1	Sink	Girls' Restroom	N	011608780-0039	EMSL	03036	12/19/2016	05:45	200.8	1/3/2017	14:33	<1.00	1.00	1	N

39-CRS-43-GIRLS-TS32-1	Sink	Girls' Restroom	N	011608780-0040	EMSL	03036	12/19/2016	05:46	200.8	1/3/2017	14:33	<1.00	1.00	1	N
40-CRS-44-CLASS-CS4-1	Sink	Classroom	N	011608780-0041	EMSL	03036	12/19/2016	05:51	200.8	1/3/2017	14:09	<1.00	1.00	1	N

**NOTES:**

18.4 = Exceeds NJDEP Action Limit of 15.5 ug/L

Qualifier