

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Reportin		Dilution Factor	Digested (Y/N)	Qualifier
											Concentrati on in ug/L	g Limit (ug/L)			
14-FHE-51-BOYS-TS14-1	Sink	Boys' Restroom	N	011608689-0015	EMSL	03036	12/15/2016	200.8	12/30/2016	19:16	17.1	1.00	1	N	
15-FHE-50-GIRLS-TS13-1	Sink	Girls' Restroom	N	011608689-0016	EMSL	03036	12/15/2016	200.8	12/30/2016	19:17	18.2	1.00	1	N	
17-FHE-3-ROOM 16-CS3-1	Sink	Classroom	N	011608689-0018	EMSL	03036	12/15/2016	200.8	12/30/2016	19:18	53.2	1.00	1	N	
22-FHE-5-ROOM 11-CS5-1	Sink	Classroom	N	011608689-0023	EMSL	03036	12/15/2016	200.8	12/29/2016	22:37	16.4	1.00	1	N	
28-FHE-12-ROOM 5-CS12-1	Sink	Classroom	N	011608689-0029	EMSL	03036	12/15/2016	200.8	12/30/2016	19:29	21.8	10.0	10	N	
FB-FIELD BLANK			N	011608689-0001	EMSL	03036	12/15/2016	200.8	12/30/2016	18:58	<1.00	1.00	1	N	
		Custodian													
1-FHE-20-CUST-TS3-1	Sink	Restroom	N	011608689-0002	EMSL	03036	12/15/2016	200.8	12/30/2016	19:00	8.75	1.00	1	N	
2-FHE-26-ROOM 28-CS21-1	Sink	Classroom	N	011608689-0003	EMSL	03036	12/15/2016	200.8	12/29/2016	22:36	7.31	1.00	1	N	
3-FHE-24-ROOM 27-CS19-1	Sink	Classroom	N	011608689-0004	EMSL	03036	12/15/2016	200.8	12/30/2016	19:03	1.58	1.00	1	N	
4-FHE-25-ROOM 26-CS20-1	Sink	Classroom	N	011608689-0005	EMSL	03036	12/15/2016	200.8	12/30/2016	19:04	12.5	1.00	1	N	
5-FHE-27-ROOM 25-CS22-1	Sink	Classroom	N	011608689-0006	EMSL	03036	12/15/2016	200.8	12/30/2016	19:05	12.3	1.00	1	N	
6-FHE-30-ROOM 24-CS25-1	Sink	Classroom	N	011608689-0007	EMSL	03036	12/15/2016	200.8	12/30/2016	19:05	<1.00	1.00	1	N	
7-FHE-28-ROOM 23-CS23-1	Sink	Classroom	N	011608689-0008	EMSL	03036	12/15/2016	200.8	12/30/2016	19:06	4.50	1.00	1	N	
8-FHE-29-ROOM 22-CS24-1	Sink	Classroom	N	011608689-0009	EMSL	03036	12/15/2016	200.8	12/30/2016	19:08	5.25	1.00	1	N	
9-FHE-31-ROOM 21-CS26-1	Sink	Classroom	N	011608689-0010	EMSL	03036	12/15/2016	200.8	12/30/2016	19:09	4.88	1.00	1	N	
10-FHE-34-ROOM 20-CS29-1	Sink	Classroom	N	011608689-0011	EMSL	03036	12/15/2016	200.8	12/30/2016	19:10	4.80	1.00	1	N	
11-FHE-32-ROOM 19-CS27-1	Sink	Classroom	N	011608689-0012	EMSL	03036	12/15/2016	200.8	12/30/2016	19:13	1.10	1.00	1	N	
12-FHE-33-ROOM 18-CS28-1	Sink	Classroom	N	011608689-0013	EMSL	03036	12/15/2016	200.8	12/30/2016	19:15	1.04	1.00	1	N	
13-FHE-35-ROOM 17-CS30-1	Sink	Classroom	N	011608689-0014	EMSL	03036	12/15/2016	200.8	12/30/2016	19:16	2.00	1.00	1	N	
16-FHE-49-PE OFFICE-TS12-1	Sink	PE Office	N	011608689-0017	EMSL	03036	12/15/2016	200.8	12/29/2016	22:36	2.38	1.00	1	N	
18-FHE-1-ROOM 15-CS1-1	Sink	Classroom	N	011608689-0019	EMSL	03036	12/15/2016	200.8	12/30/2016	19:20	2.06	1.00	1	N	
19-FHE-2-ROOM 14-CS2-1	Sink	Classroom	N	011608689-0020	EMSL	03036	12/15/2016	200.8	12/30/2016	19:21	5.67	1.00	1	N	
20-FHE-4-ROOM 13-CS4-1	Sink	Classroom	N	011608689-0021	EMSL	03036	12/15/2016	200.8	12/30/2016	19:21	1.47	1.00	1	N	
21-FHE-7-ROOM 12-CS7-1	Sink	Classroom	N	011608689-0022	EMSL	03036	12/15/2016	200.8	12/30/2016	19:22	2.45	1.00	1	N	
23-FHE-6-ROOM 10-CS6-1	Sink	Classroom	N	011608689-0024	EMSL	03036	12/15/2016	200.8	12/30/2016	19:23	4.05	1.00	1	N	
24-FHE-8-ROOM 9-CS8-1	Sink	Classroom	N	011608689-0025	EMSL	03036	12/15/2016	200.8	12/30/2016	19:25	9.67	1.00	1	N	
25-FHE-11-ROOM 8-CS11-1	Sink	Classroom	N	011608689-0026	EMSL	03036	12/15/2016	200.8	12/30/2016	19:25	2.70	1.00	1	N	
26-FHE-9-ROOM 7-CS9-1	Sink	Classroom	N	011608689-0027	EMSL	03036	12/15/2016	200.8	12/30/2016	19:26	8.72	1.00	1	N	
27-FHE-10-ROOM 6-CS10-1	Sink	Classroom	N	011608689-0028	EMSL	03036	12/15/2016	200.8	12/29/2016	22:38	10.4	1.00	1	N	
29-FHE-15-ROOM 4-CS13-1	Sink	Classroom	N	011608689-0030	EMSL	03036	12/15/2016	200.8	12/30/2016	19:30	3.09	1.00	1	N	
30-FHE-13-ROOM 3-CS13-1	Sink	Classroom	N	011608689-0031	EMSL	03036	12/15/2016	200.8	12/29/2016	22:38	7.44	1.00	1	N	
31-FHE-16-ROOM 1-CS16-1	Sink	Classroom	N	011608689-0032	EMSL	03036	12/15/2016	200.8	12/29/2016	22:41	6.14	1.00	1	N	
32-FHE-17-NURSE-CS17-1	Sink	Classroom	N	011608689-0033	EMSL	03036	12/15/2016	200.8	12/30/2016	19:30	2.67	1.00	1	N	
33-FHE-19-NURSE TOILET-TS2-1	Sink	Nurses' Office	N	011608689-0034	EMSL	03036	12/15/2016	200.8	12/30/2016	19:31	2.15	1.00	1	N	

TOILET-TS1-1	Sink	Restroom	N	011608689-0035	EMSL	03036	12/15/2016	200.8	12/30/2016	19:32	12.0	1.00	1	N
35-FHE-48-ROOM 30-SS4-1			N	011608689-0036	EMSL	03036	12/15/2016	200.8	12/30/2016	19:32	<1.00	1.00	1	N
36-FHE-36-BOYS-TS4-1	Sink	Boys' Restroom	N	011608689-0037	EMSL	03036	12/15/2016	200.8	12/30/2016	2:41	1.23	1.00	1	N
37-FHE-37-BOYS-TS5-1	Sink	Boys' Restroom	N	011608689-0038	EMSL	03036	12/15/2016	200.8	12/30/2016	2:43	<1.00	1.00	1	N
38-FHE-38-BOYS-TS6-1	Sink	Boys' Restroom	N	011608689-0039	EMSL	03036	12/15/2016	200.8	12/30/2016	2:45	1.54	1.00	1	N
39-FHE-40-GIRLS-TS7-1	Sink	Girls' Restroom	N	011608689-0040	EMSL	03036	12/15/2016	200.8	12/30/2016	2:46	2.30	1.00	1	N
40-FHE-41-GIRLS-TS8-1	Sink	Girls' Restroom	N	011608689-0041	EMSL	03036	12/15/2016	200.8	12/30/2016	2:46	8.95	1.00	1	N
41-FHE-42-GIRLS-TS9-1	Sink	Girls' Restroom	N	011608689-0042	EMSL	03036	12/15/2016	200.8	12/30/2016	2:47	2.25	1.00	1	N
CS35-1	Sink	Classroom	N	011608689-0045	EMSL	03036	12/15/2016	200.8	12/30/2016	2:49	<1.00	1.00	1	N
CS36-1	Sink	Classroom	N	011608689-0046	EMSL	03036	12/15/2016	200.8	12/30/2016	2:50	4.57	1.00	1	N

**NOTES:**

18.4 = Exceeds NJDEP Action Limit of 15.5 ug/L

Comments

CS-15 on Map