

| Field ID | Type | Location | Flushed Y/N | Laboratory Sample ID | Laboratory Name | Lab Certification ID | Date Sampled | Analytical Method | Date of Analysis | Time of Analysis | Concentration in ug/L | Reporting Limit (ug/L) | Dilution Factor | Digested (Y/N) |
|--------------------------|-----------------|-----------|-------------|----------------------|-----------------|----------------------|--------------|-------------------|------------------|------------------|-----------------------|------------------------|-----------------|----------------|
| FB-FIELD BLANK | | | N | 011609021-0001 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 13:44 | <1.00 | 1.00 | 1 | N |
| 1-HBW-1-CLASS-CSB1-1 | Sink w/ bubbler | Classroom | N | 011609021-0002 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:04 | <1.00 | 1.00 | 1 | N |
| 2-HBW-119-CLASS-CS26-1 | Sink | Classroom | N | 011609021-0003 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:06 | <1.00 | 1.00 | 1 | N |
| 3-HBW-2-C TOILET-TS1-1 | Sink | Restroom | N | 011609021-0004 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:06 | 2.52 | 1.00 | 1 | N |
| 4-HBW-3-CLASS-CSB2-1 | Sink w/ bubbler | Classroom | N | 011609021-0005 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:07 | <1.00 | 1.00 | 1 | N |
| 5-HBW-120-CLASS-CS27-1 | Sink | Classroom | N | 011609021-0006 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:08 | <1.00 | 1.00 | 1 | N |
| 6-HBW-4-C TOILET-TS2-1 | Sink | Restroom | N | 011609021-0007 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:10 | 1.32 | 1.00 | 1 | N |
| 7-HBW-5-CLASS-CSB3-1 | Sink w/ bubbler | Classroom | N | 011609021-0008 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:10 | <1.00 | 1.00 | 1 | N |
| 8-HBW-121-CLASS-CS28-1 | Sink | Classroom | N | 011609021-0009 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:11 | <1.00 | 1.00 | 1 | N |
| 9-HBW-6-C TOILET-TS3-1 | Sink | Restroom | N | 011609021-0010 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:12 | 3.10 | 1.00 | 1 | N |
| 10-HBW-7-CLASS-CSB4-1 | Sink w/ bubbler | Classroom | N | 011609021-0011 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:12 | <1.00 | 1.00 | 1 | N |
| 11-HBW-122-CLASS-CS29-1 | Sink | Classroom | N | 011609021-0012 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:13 | 1.17 | 1.00 | 1 | N |
| 12-HBW-8-C TOILET-TS4-1 | Sink | Restroom | N | 011609021-0013 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:15 | 23.4 | 1.00 | 1 | N |
| 13-HBW-9-CLASS-CSB5-1 | Sink w/ bubbler | Classroom | N | 011609021-0014 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:16 | <1.00 | 1.00 | 1 | N |
| 14-HBW-123-CLASS-CS30-1 | Sink | Classroom | N | 011609021-0015 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:18 | <1.00 | 1.00 | 1 | N |
| 15-HBW-10-C TOILET-TS5-1 | Sink | Restroom | N | 011609021-0016 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:19 | 2.02 | 1.00 | 1 | N |
| 16-HBW-11-CLASS-CSB6-1 | Sink w/ bubbler | Classroom | N | 011609021-0017 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:19 | <1.00 | 1.00 | 1 | N |
| 17-HBW-124-CLASS-CS31-1 | Sink | Classroom | N | 011609021-0018 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:20 | 1.95 | 1.00 | 1 | N |
| 18-HBW-12-C TOILET-TS6-1 | Sink | Restroom | N | 011609021-0019 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:21 | 37.5 | 1.00 | 1 | N |
| 19-HBW-13-CLASS-CSB7-1 | Sink w/ bubbler | Classroom | N | 011609021-0020 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:21 | <1.00 | 1.00 | 1 | N |
| 20-HBW-125-CLASS-CS32-1 | Sink | Classroom | N | 011609021-0021 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:22 | <1.00 | 1.00 | 1 | N |
| 21-HBW-14-C TOILET-TS7-1 | Sink | Restroom | N | 011609021-0022 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:27 | 24.4 | 1.00 | 1 | N |
| 22-HBW-15-CLASS-CSB8-1 | Sink w/ bubbler | Classroom | N | 011609021-0023 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:29 | 1.21 | 1.00 | 1 | N |
| 23-HBW-126-CLASS-CS33-1 | Sink | Classroom | N | 011609021-0024 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:30 | <1.00 | 1.00 | 1 | N |
| 24-HBW-16-C TOILET-TS8-1 | Sink | Restroom | N | 011609021-0025 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:30 | 3.23 | 1.00 | 1 | N |
| 25-HBW-127-CLASS-CSB35-1 | Sink w/ bubbler | Classroom | N | 011609021-0026 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:31 | <1.00 | 1.00 | 1 | N |
| 26-HBW-128-CLASS-CS34-1 | Sink | Classroom | N | 011609021-0027 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:32 | 1.36 | 1.00 | 1 | N |

| | | | | | | | | | | | | | |
|--------------------------|------|---------------------|---|----------------|------|-------|------------|-------|----------|-------|-------|------|-----|
| 27-HBW-18-C TOILET-TS9-1 | Sink | Restroom Mens' | N | 011609021-0028 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:34 | 2.53 | 1.00 | 1 N |
| 28-HBW-19-MENS-TS10-1 | Sink | Restroom Mens' | N | 011609021-0029 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:35 | <1.00 | 1.00 | 1 N |
| 29-HBW-20-MENS-TS11-1 | Sink | Restroom Womens' | N | 011609021-0030 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:35 | <1.00 | 1.00 | 1 N |
| 30-HBW-21-WOMENS-TS12-1 | Sink | Restroom Womens' | N | 011609021-0031 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:36 | 1.47 | 1.00 | 1 N |
| 31-HBW-22-WOMENS-TS13-1 | Sink | Restroom Womens' | N | 011609021-0032 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:37 | 4.07 | 1.00 | 1 N |
| 32-HBW-23-WOMENS-TS14-1 | Sink | Restroom | N | 011609021-0033 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:39 | 2.82 | 1.00 | 1 N |
| 33-HBW-24-CLASS-CS10-1 | Sink | Classroom Boys' | N | 011609021-0034 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:39 | 2.88 | 1.00 | 1 N |
| 34-HBW-25-BOYS-TS15-1 | Sink | Restroom Boys' | N | 011609021-0035 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:40 | 3.18 | 1.00 | 1 N |
| 35-HBW-26-BOYS-TS16-1 | Sink | Restroom Boys' | N | 011609021-0036 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:42 | 1.58 | 1.00 | 1 N |
| 36-HBW-27-BOYS-TS17-1 | Sink | Restroom Boys' | N | 011609021-0037 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:43 | 1.29 | 1.00 | 1 N |
| 37-HBW-28-BOYS-TS18-1 | Sink | Restroom Boys' | N | 011609021-0038 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:43 | 1.39 | 1.00 | 1 N |
| 38-HBW-29-BOYS-TS19-1 | Sink | Restroom Girls' | N | 011609021-0039 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:44 | 1.74 | 1.00 | 1 N |
| 39-HBW-30-GIRLS-TS20-1 | Sink | Restroom Girls' | N | 011609021-0040 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:45 | 3.00 | 1.00 | 1 N |
| 40-HBW-31-GIRLS-TS21-1 | Sink | Restroom Girls' | N | 011609021-0041 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:46 | <1.00 | 1.00 | 1 N |
| 41-HBW-32-GIRLS-TS22-1 | Sink | Restroom Girls' | N | 011609021-0042 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:45 | 1.20 | 1.00 | 1 N |
| 42-HBW-33-GIRLS-TS23-1 | Sink | Restroom Girls' | N | 011609021-0043 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:56 | 1.07 | 1.00 | 1 N |
| 43-HBW-34-GIRLS-TS24-1 | Sink | Restroom Girls' | N | 011609021-0044 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:47 | 1.08 | 1.00 | 1 N |
| 44-HBW-35-GIRLS-TS25-1 | Sink | Restroom Girls' | N | 011609021-0045 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:59 | <1.00 | 1.00 | 1 N |
| 45-HBW-36-GIRLS-TS26-1 | Sink | Restroom | N | 011609021-0046 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 17:59 | 1.60 | 1.00 | 1 N |
| 46-HBW-38-ART-CS11-1 | Sink | Classroom | N | 011609021-0047 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:00 | 1.03 | 1.00 | 1 N |
| 47-HBW-39-ART-CS12-1 | Sink | Classroom | N | 011609021-0048 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:01 | 28.8 | 1.00 | 1 N |

| | | | | | | | | | | | | | |
|--------------------------------|------|---------------------|---|----------------|------|-------|------------|-------|-----------|-------|-------|------|-----|
| 48-HBW-40-ART ST-CS13-1 | Sink | Classroom | N | 011609021-0049 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:47 | 33.2 | 1.00 | 1 N |
| 49-HBW-41-OFFICE PANTRY-CS14-1 | Sink | Office | N | 011609021-0050 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:03 | <1.00 | 1.00 | 1 N |
| 50-HBW-42-NURSE TOILET-TS27-1 | Sink | Nurse's Office | N | 011609021-0051 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:04 | 1.44 | 1.00 | 1 N |
| 51-HBW-43-OFFICE TOILET-TS28-1 | Sink | Restroom | N | 011609021-0052 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:05 | 16.2 | 1.00 | 1 N |
| 52-HBW-44-OFFICE TOILET-TS29-1 | Sink | Restroom | N | 011609021-0053 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:05 | 1.58 | 1.00 | 1 N |
| 53-HBW-45-NURSE-CS15-1 | Sink | Nurse's Office | N | 011609021-0054 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:06 | 3.28 | 1.00 | 1 N |
| 54-HBW-46-NURSE-CS16-1 | Sink | Nurse's Office | N | 011609021-0055 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:09 | 11.4 | 1.00 | 1 N |
| 55-HBW-129-CLASS-CS35-1 | Sink | Classroom | N | 011609021-0056 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:09 | <1.00 | 1.00 | 1 N |
| 56-HBW-47-SERVING-KS1-1 | Sink | Kitchen | N | 011609021-0057 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:48 | 1.12 | 1.00 | 1 N |
| 57-HBW-48-KITCHEN-KS2-1 | Sink | Kitchen | N | 011609021-0058 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:49 | 6.50 | 1.00 | 1 N |
| 58-HBW-49-KITCHEN-KS3-1 | Sink | Kitchen | N | 011609021-0059 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:51 | <1.00 | 1.00 | 1 N |
| 59-HBW-50-KITCHEN-KS4-1 | Sink | Kitchen | N | 011609021-0060 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:12 | 4.11 | 1.00 | 1 N |
| 60-HBW-51-KITCHEN-KS5-1 | Sink | Kitchen | N | 011609021-0061 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:12 | 6.96 | 1.00 | 1 N |
| 61-HBW-52-KITCHEN-KS6-1 | Sink | Kitchen | N | 011609021-0062 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:13 | <1.00 | 1.00 | 1 N |
| 62-HBW-130-KITCHEN-IM1-1 | Sink | Kitchen | N | 011609021-0063 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:51 | <1.00 | 1.00 | 1 N |
| 62A-HBW-130-KITCHEN-IM1-2 | Sink | Kitchen | N | 011609021-0064 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/13/2017 | 10:23 | <1.00 | 1.00 | 1 N |
| 63-HBW-131-KITCHEN-KS7-1 | Sink | Kitchen | N | 011609021-0065 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:14 | 6.72 | 1.00 | 1 N |
| 64-HBW-53-WOMENS-TS30-1 | Sink | Restroom Womens' | N | 011609021-0066 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:52 | <1.00 | 1.00 | 1 N |
| 65-HBW-54-WOMENS-TS31-1 | Sink | Restroom Womens' | N | 011609021-0067 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:53 | 2.48 | 1.00 | 1 N |
| 66-HBW-55-MENS-TS32-1 | Sink | Restroom Mens' | N | 011609021-0068 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:53 | 3.49 | 1.00 | 1 N |
| 67-HBW-56-MENS-TS33-1 | Sink | Restroom Mens' | N | 011609021-0069 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:14 | 6.38 | 1.00 | 1 N |
| 68-HBW-57-GIRLS-TS34-1 | Sink | Restroom Girls' | N | 011609021-0070 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:15 | 2.52 | 1.00 | 1 N |
| 69-HBW-58-GIRLS-TS35-1 | Sink | Restroom Girls' | N | 011609021-0071 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:55 | 1.09 | 1.00 | 1 N |
| 70-HBW-59-GIRLS-TS36-1 | Sink | Restroom Girls' | N | 011609021-0072 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:56 | 2.20 | 1.00 | 1 N |
| 71-HBW-60-GIRLS-TS37-1 | Sink | Restroom Girls' | N | 011609021-0073 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:16 | 3.59 | 1.00 | 1 N |

| | | | | | | | | | | | | | |
|--------------------------|------|--------------------|---|----------------|------|-------|------------|-------|----------|-------|-------|------|-----|
| 72-HBW-61-GIRLS-TS38-1 | Sink | Girls' Restroom | N | 011609021-0074 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/3/2017 | 18:07 | 1.30 | 1.00 | 1 N |
| 73-HBW-62-GIRLS-TS39-1 | Sink | Girls' Restroom | N | 011609021-0075 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 19:57 | <1.00 | 1.00 | 1 N |
| 74-HBW-63-GIRLS-TS40-1 | Sink | Girls' Restroom | N | 011609021-0076 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:35 | 3.07 | 1.00 | 1 N |
| 75-HBW-64-GIRLS-TS41-1 | Sink | Girls' Restroom | N | 011609021-0077 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:37 | 2.47 | 1.00 | 1 N |
| 76-HBW-65-GIRLS-TS42-1 | Sink | Girls' Restroom | N | 011609021-0078 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:38 | 2.62 | 1.00 | 1 N |
| 77-HBW-66-GIRLS-TS43-1 | Sink | Girls' Restroom | N | 011609021-0079 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:39 | 2.81 | 1.00 | 1 N |
| 78-HBW-67-BOYS-TS44-1 | Sink | Boys' Restroom | N | 011609021-0080 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:39 | 1.32 | 1.00 | 1 N |
| 79-HBW-68-BOYS-TS45-1 | Sink | Boys' Restroom | N | 011609021-0081 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:40 | 2.38 | 1.00 | 1 N |
| 80-HBW-69-BOYS-TS46-1 | Sink | Boys' Restroom | N | 011609021-0082 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:42 | 2.58 | 1.00 | 1 N |
| 81-HBW-70-BOYS-TS47-1 | Sink | Boys' Restroom | N | 011609021-0083 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:43 | 1.46 | 1.00 | 1 N |
| 82-HBW-71-BOYS-TS48-1 | Sink | Boys' Restroom | N | 011609021-0084 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:43 | 1.78 | 1.00 | 1 N |
| 83-HBW-72-BOYS-TS49-1 | Sink | Boys' Restroom | N | 011609021-0085 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:44 | 2.37 | 1.00 | 1 N |
| 84-HBW-73-BOYS-TS50-1 | Sink | Boys' Restroom | N | 011609021-0086 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:45 | 2.48 | 1.00 | 1 N |
| 85-HBW-74-BOYS-TS51-1 | Sink | Boys' Restroom | N | 011609021-0087 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:47 | 2.01 | 1.00 | 1 N |
| 86-HBW-75-BOYS-TS52-1 | Sink | Boys' Restroom | N | 011609021-0088 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:48 | 2.37 | 1.00 | 1 N |
| 87-HBW-76-BOYS-TS53-1 | Sink | Boys' Restroom | N | 011609021-0089 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:48 | 2.19 | 1.00 | 1 N |
| 88-HBW-80-LIBRARY-CS17-1 | Sink | Library | N | 011609021-0090 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:50 | 2.49 | 1.00 | 1 N |
| 89-HBW-81-CLASS-CS18-1 | Sink | Classroom | N | 011609021-0091 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:51 | <1.00 | 1.00 | 1 N |
| 90-HBW-132-CLASS-CS28-1 | Sink | Classroom | N | 011609021-0092 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:52 | 11.9 | 1.00 | 1 N |
| 91-HBW-88-GIRLS-TS54-1 | Sink | Girls' Restroom | N | 011609021-0093 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:52 | <1.00 | 1.00 | 1 N |

| | | | | | | | | | | | | | |
|--|----------------------|---------------------|---|----------------|------|-------|------------|-------|-----------|-------|-------|------|-----|
| 92-HBW-89-GIRLS-TS55-1 | Sink | Girls' Restroom | N | 011609021-0094 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:53 | <1.00 | 1.00 | 1 N |
| 93-HBW-90-GIRLS-TS56-1 | Sink | Girls' Restroom | N | 011609021-0095 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 12:54 | <1.00 | 1.00 | 1 N |
| 94-HBW-91-GIRLS-TS57-1 | Sink | Girls' Restroom | N | 011609021-0096 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:02 | <1.00 | 1.00 | 1 N |
| 95-HBW-92-GIRLS-TS58-1 | Sink | Girls' Restroom | N | 011609021-0097 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:04 | <1.00 | 1.00 | 1 N |
| 96-HBW-93-GIRLS-TS59-1 | Sink | Girls' Restroom | N | 011609021-0098 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:05 | 1.06 | 1.00 | 1 N |
| 97-HBW-94-GIRLS-TS60-1 | Sink | Girls' Restroom | N | 011609021-0099 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:05 | 1.20 | 1.00 | 1 N |
| 98-HBW-95-BOYS-TS61-1 | Sink | Boys' Restroom | N | 011609021-0100 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:06 | 1.05 | 1.00 | 1 N |
| 99-HBW-96-BOYS-TS62-1 | Sink | Boys' Restroom | N | 011609021-0101 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:08 | <1.00 | 1.00 | 1 N |
| 100-HBW-97-BOYS-TS63-1 | Sink | Boys' Restroom | N | 011609021-0102 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:09 | <1.00 | 1.00 | 1 N |
| 101-HBW-98-BOYS-TS64-1 | Sink | Boys' Restroom | N | 011609021-0103 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:10 | <1.00 | 1.00 | 1 N |
| 102-HBW-99-BOYS-TS65-1 | Sink | Boys' Restroom | N | 011609021-0104 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:10 | 1.72 | 1.00 | 1 N |
| 103-HBW-103-CLASS-CS25-1 | Sink | Classroom | N | 011609021-0105 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:11 | 5.71 | 1.00 | 1 N |
| 104-HBW-104-WOMENS-TS67-1 | Sink | Womens' Restroom | N | 011609021-0106 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:12 | <1.00 | 1.00 | 1 N |
| 105-HBW-105-WOMENS-TS68-1 | Sink | Womens' Restroom | N | 011609021-0107 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:14 | 1.76 | 1.00 | 1 N |
| 106-HBW-106-WOMENS-TS69-1 | Sink | Womens' Restroom | N | 011609021-0108 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:14 | 8.39 | 1.00 | 1 N |
| 107-HBW-107-MENS-TS70-1 | Sink | Mens' Restroom | N | 011609021-0109 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:16 | <1.00 | 1.00 | 1 N |
| 108-HBW-108-MENS-TS71-1 | Sink | Mens' Restroom | N | 011609021-0110 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:17 | 6.93 | 1.00 | 1 N |
| 109-HBW-133-CLASS-CS36-1 | Sink | Classroom | N | 011609021-0111 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:18 | <1.00 | 1.00 | 1 N |
| 110-HBW-110-CLASS-CSB26-1 | Sink w/ bubbler | Classroom | N | 011609021-0112 | EMSL | 03036 | 12/29/2016 | 200.8 | 1/4/2017 | 13:18 | <1.00 | 1.00 | 1 N |
| 1-HBW-78-DRINK FOUNTAIN-CORRIDOR-DF1-1 | Drinking Fountain | Corridor | N | 011700606-0001 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:54 | <1.00 | 1 | 1 N |

| | | | | | | | | | | | | | |
|---|-------------------|----------|---|----------------|------|-------|-----------|-------|-----------|-------------|------|---|-----|
| 2-HBW-79-DRINK FOUNTAIN-CORRIDOR-DF2-1 | Drinking Fountain | Corridor | N | 011700606-0002 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:34 | 1.79 | 1 | 1 N |
| 3-HBW-E1-DRINK FOUNTAIN-CORRIDOR-EDF1-1 | Drinking Fountain | Corridor | N | 011700606-0003 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:39 | 1.69 | 1 | 1 N |
| 4-HBW-E2-DRINK FOUNTAIN-CORRIDOR-EDF2-1 | Drinking Fountain | Corridor | N | 011700606-0004 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:40 <1.00 | | 1 | 1 N |
| 5-HBW-101-DRINK FOUNTAIN-CORRIDOR-DF3-1 | Drinking Fountain | Corridor | N | 011700606-0005 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:40 <1.00 | | 1 | 1 N |
| 6-HBW-102-DRINK FOUNTAIN-CORRIDOR-DF4-1 | Drinking Fountain | Corridor | N | 011700606-0006 | EMSL | 03036 | 1/24/2017 | 200.8 | 1/24/2017 | 22:41 <1.00 | | 1 | 1 N |