

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
MCG-3-TOILET-TS1-1	Sink	Toilet	N	011701571-0001	EMSL	03036	2/28/2017	200.8	3/2/2017	10:38	2.05	1.00	1	N
MCG-4-CLASS-CS1-1	Sink	Classroom	N	011701571-0002	EMSL	03036	2/28/2017	200.8	3/2/2017	10:39	<1.00	1.00	1	N
MCG-5-TOILET-TS2-1	Sink	Toilet	N	011701571-0003	EMSL	03036	2/28/2017	200.8	3/2/2017	10:40	1.39	1.00	1	N
MCG-6-CLASS-CS2-1	Sink	Classroom	N	011701571-0004	EMSL	03036	2/28/2017	200.8	3/2/2017	10:40	1.22	1.00	1	N
MCG-7-TOILET-TS3-1	Sink	Toilet	N	011701571-0005	EMSL	03036	2/28/2017	200.8	3/2/2017	10:41	1.32	1.00	1	N
MCG-8-CLASS-CS3-1	Sink	Classroom	N	011701571-0006	EMSL	03036	2/28/2017	200.8	3/2/2017	10:43	1.14	1.00	1	N
MCG-9-TOILET-TS4-1	Sink	Toilet	N	011701571-0007	EMSL	03036	2/28/2017	200.8	3/2/2017	10:49	1.50	1.00	1	N
MCG-10-CLASS-CS4-1	Sink	Classroom	N	011701571-0008	EMSL	03036	2/28/2017	200.8	3/2/2017	10:49	7.51	1.00	1	N
1-MCG-1-KITCHEN-KS1-1	Sink	Kitchen	N	011608842-0002	EMSL	03036	12/22/2016	200.8	1/3/2017	14:47	2.55	1.00	1	N
2-MCG-2-KITCHEN-KS2-1	Sink	Kitchen	N	011608842-0003	EMSL	03036	12/22/2016	200.8	1/3/2017	14:48	5.79	1.00	1	N
3-MCG-11-KITCHEN-KS3-1	Sink	Kitchen	N	011608842-0004	EMSL	03036	12/22/2016	200.8	1/3/2017	14:49	1.46	1.00	1	N
4-MCG-12-KITCHEN-KS4-1	Sink	Kitchen	N	011608842-0005	EMSL	03036	12/22/2016	200.8	1/3/2017	14:50	1.74	1.00	1	N