

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	n	Digestion Factor (Y/N)
FB-FIELD BLANK			N	011608691-0001	EMSL	03036	12/16/2016	200.8	12/30/2016	18:26	<1.00	1.00	1	N
1-SES-1-BASE TOILET-TS1-1	Sink	Restroom	N	011608691-0002	EMSL	03036	12/16/2016	200.8	12/30/2016	18:29	3.11	1.00	1	N
2-SES-27-BOYS-TS15-1	Sink	Boys' Restroom	N	011608691-0003	EMSL	03036	12/16/2016	200.8	12/30/2016	18:30	1.05	1.00	1	N
3-SES-28-BOYS-TS16-1	Sink	Boys' Restroom	N	011608691-0004	EMSL	03036	12/16/2016	200.8	12/30/2016	18:31	<1.00	1.00	1	N
4-SES-29-BOYS-TS17-1	Sink	Boys' Restroom	N	011608691-0005	EMSL	03036	12/16/2016	200.8	12/29/2016	22:42	371	10.0	10	N
5-SES-30-BOYS-TS18-1	Sink	Boys' Restroom	N	011608691-0006	EMSL	03036	12/16/2016	200.8	12/30/2016	18:31	2.49	1.00	1	N
6-SES-31-BOYS-TS19-1	Sink	Boys' Restroom	N	011608691-0007	EMSL	03036	12/16/2016	200.8	12/30/2016	18:32	2.07	1.00	1	N
7-SES-24-KITCHEN-KS1-1	Sink	Kitchen	N	011608691-0008	EMSL	03036	12/16/2016	200.8	12/30/2016	18:33	1.49	1.00	1	N
8-SES-25-KITCHEN-KS2-1	Sink	Kitchen	N	011608691-0009	EMSL	03036	12/16/2016	200.8	12/30/2016	18:34	<1.00	1.00	1	N
9-SES-18-GIRLS-TS10-1	Sink	Girls' Restroom	N	011608691-0010	EMSL	03036	12/16/2016	200.8	12/30/2016	18:34	1.14	1.00	1	N
10-SES-19-GIRLS-TS11-1	Sink	Girls' Restroom	N	011608691-0011	EMSL	03036	12/16/2016	200.8	12/30/2016	18:35	3.63	1.00	1	N
11-SES-20-GIRLS-TS12-1	Sink	Girls' Restroom	N	011608691-0012	EMSL	03036	12/16/2016	200.8	12/30/2016	18:37	2.00	1.00	1	N
12-SES-21-GIRLS-TS13-1	Sink	Girls' Restroom	N	011608691-0013	EMSL	03036	12/16/2016	200.8	12/30/2016	18:39	<1.00	1.00	1	N
13-SES-22-GIRLS-TS14-1	Sink	Girls' Restroom	N	011608691-0014	EMSL	03036	12/16/2016	200.8	12/29/2016	22:41	328	10.0	10	N
14-SES-8-NURSE-CS7-1	Sink	Nurse's Office	N	011608691-0015	EMSL	03036	12/16/2016	200.8	12/30/2016	18:40	2.02	1.00	1	N
15-SES-11-GIRLS-TS4-1	Sink	Girls' Restroom	N	011608691-0016	EMSL	03036	12/16/2016	200.8	12/30/2016	18:40	2.87	1.00	1	N
16-SES-10-GIRLS-TS3-1	Sink	Girls' Restroom	N	011608691-0017	EMSL	03036	12/16/2016	200.8	12/30/2016	18:41	2.77	1.00	1	N
17-SES-9-GIRLS-TS2-1	Sink	Girls' Restroom	N	011608691-0018	EMSL	03036	12/16/2016	200.8	12/30/2016	18:42	<1.00	1.00	1	N
18-SES-15-BOYS-TS7-1	Sink	Boys' Restroom	N	011608691-0019	EMSL	03036	12/16/2016	200.8	12/30/2016	18:43	2.47	1.00	1	N
19-SES-14-BOYS-TS6-1	Sink	Boys' Restroom	N	011608691-0020	EMSL	03036	12/16/2016	200.8	12/30/2016	18:43	<1.00	1.00	1	N
20-SES-13-BOYS-TS5-1	Sink	Boys' Restroom	N	011608691-0021	EMSL	03036	12/16/2016	200.8	12/30/2016	18:45	1.19	1.00	1	N
21-SES-5-ROOM 22-CS4-1	Sink	Nurse's Office	N	011608691-0022	EMSL	03036	12/16/2016	200.8	12/30/2016	18:46	1.74	1.00	1	N
22-SES-16-ROOM 24-TS8-1	Sink	Restroom	N	011608691-0023	EMSL	03036	12/16/2016	200.8	12/30/2016	18:48	<1.00	1.00	1	N
23-SES-17-ROOM 23-TS9-1	Sink	Restroom	N	011608691-0024	EMSL	03036	12/16/2016	200.8	12/30/2016	18:50	3.17	1.00	1	N
24-SES-7-ROOM 23-CS6-1	Sink	Nurse's Office	N	011608691-0025	EMSL	03036	12/16/2016	200.8	12/30/2016	18:51	2.44	1.00	1	N
25-SES-6-ROOM 24-CS5-1	Sink	Nurse's Office	N	011608691-0026	EMSL	03036	12/16/2016	200.8	12/30/2016	18:51	1.99	1.00	1	N
26-SES-4-ROOM 21-CS3-1	Sink	Nurse's Office	N	011608691-0027	EMSL	03036	12/16/2016	200.8	12/30/2016	18:54	1.14	1.00	1	N
27-SES-3-ROOM 18-CS2-1	Sink	Nurse's Office	N	011608691-0028	EMSL	03036	12/16/2016	200.8	12/30/2016	18:55	1.04	1.00	1	N
28-SES-2-ROOM 17-CS1-1	Sink	Nurse's Office	N	011608691-0029	EMSL	03036	12/16/2016	200.8	12/30/2016	18:56	4.05	1.00	1	N
29-SES-33-TOILET-TS21-1	Sink	Restroom	N	011608691-0030	EMSL	03036	12/16/2016	200.8	12/30/2016	18:56	1.63	1.00	1	N
30-SES-32-TOILET-TS20-1	Sink	Restroom	N	011608691-0031	EMSL	03036	12/16/2016	200.8	12/30/2016	18:57	3.35	1.00	1	N
31-SES-34-ROOM 2-CS8-1	Sink	Nurse's Office	N	011608691-0032	EMSL	03036	12/16/2016	200.8	12/30/2016	18:58	5.62	1.00	1	N