

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-Field Blank			N	011608742-0001	EMSL	03036	12/19/2016	200.8	12/29/2016	21:47	<1.00	1.00	1	N
1-SUS-2-Kitchen-KS2-1	Sink	Kitchen	N	011608742-0002	EMSL	03036	12/19/2016	200.8	12/29/2016	21:50	350	10.0	10	N
2-SUS-2-Kitchen-KS1-1	Sink	Kitchen	N	011608742-0003	EMSL	03036	12/19/2016	200.8	12/29/2016	21:51	1.36	1.00	1	N
3-SUS-4-Toilet-TS2-1	Sink	Restroom	N	011608742-0004	EMSL	03036	12/19/2016	200.8	12/29/2016	21:52	1.72	1.00	1	N
4-SUS-3-Toilet-TS1-1	Sink	Restroom	N	011608742-0005	EMSL	03036	12/19/2016	200.8	12/29/2016	21:53	1.62	1.00	1	N
5-SUS-7-Toilet-TS4-1	Sink	Restroom	N	011608742-0006	EMSL	03036	12/19/2016	200.8	12/29/2016	21:53	<1.00	1.00	1	N
6-SUS-6-Toilet-TS3-1	Sink	Restroom	N	011608742-0007	EMSL	03036	12/19/2016	200.8	12/29/2016	21:54	<1.00	1.00	1	N
7-SUS-8-Classroom-CS1-1	Sink	Classroom	N	011608742-0008	EMSL	03036	12/19/2016	200.8	12/29/2016	21:55	<1.00	1.00	1	N
8-SUS-11-Classroom-CS4-1	Sink	Classroom	N	011608742-0009	EMSL	03036	12/19/2016	200.8	12/29/2016	21:55	11.1	1.00	1	N
9-SUS-33-Toilet-TS19-1	Sink	Restroom	N	011608742-0010	EMSL	03036	12/19/2016	200.8	12/29/2016	21:56	<1.00	1.00	1	N
10-SUS-37-Toilet-TS21-1	Sink	Restroom	N	011608742-0011	EMSL	03036	12/19/2016	200.8	12/29/2016	21:57	3.07	1.00	1	N
11-SUS-32-Toilet-TS17-1	Sink	Restroom	N	011608742-0012	EMSL	03036	12/19/2016	200.8	12/29/2016	22:00	1.44	1.00	1	N
12-SUS-30-Classroom-CS10-1	Sink	Classroom	N	011608742-0013	EMSL	03036	12/19/2016	200.8	12/29/2016	22:01	<1.00	1.00	1	N
13-SUS-28-Classroom-CS8-1	Sink	Classroom	N	011608742-0014	EMSL	03036	12/19/2016	200.8	12/29/2016	22:02	<1.00	1.00	1	N
14-SUS-26-Toilet-TS15-1	Sink	Restroom	N	011608742-0015	EMSL	03036	12/19/2016	200.8	12/29/2016	22:02	4.74	1.00	1	N
15-SUS-29-Classroom-CS9-1	Sink	Classroom	N	011608742-0016	EMSL	03036	12/19/2016	200.8	12/29/2016	22:03	1.61	1.00	1	N
16-SUS-31-Classroom-CS11-1	Sink	Classroom	N	011608742-0017	EMSL	03036	12/19/2016	200.8	12/29/2016	22:04	<1.00	1.00	1	N
17-SUS-34-Toilet-TS18-1	Sink	Restroom	N	011608742-0018	EMSL	03036	12/19/2016	200.8	12/29/2016	22:04	2.17	1.00	1	N
18-SUS-38-Toilet-TS22-1	Sink	Restroom	N	011608742-0019	EMSL	03036	12/19/2016	200.8	12/29/2016	22:05	2.10	1.00	1	N
19-SUS-39-Classroom-CS12-1	Sink	Classroom	N	011608742-0020	EMSL	03036	12/19/2016	200.8	12/29/2016	22:07	<1.00	1.00	1	N
20-SUS-40-Classroom-CS13-1	Sink	Classroom	N	011608742-0021	EMSL	03036	12/19/2016	200.8	12/30/2016	1:34	5.32	1.00	1	N
21-SUS-36-Toilet-TS20-1	Sink	Restroom	N	011608742-0022	EMSL	03036	12/19/2016	200.8	12/30/2016	1:36	1.47	1.00	1	N
22-SUS-42-Classroom-CS15-1	Sink	Classroom	N	011608742-0023	EMSL	03036	12/19/2016	200.8	12/30/2016	1:38	<1.00	1.00	1	N
23-SUS-44-Toilet-TS24-1	Sink	Restroom	N	011608742-0024	EMSL	03036	12/19/2016	200.8	12/30/2016	1:39	2.08	1.00	1	N
24-SUS-41-Classroom-CS14-1	Sink	Classroom	N	011608742-0025	EMSL	03036	12/19/2016	200.8	12/30/2016	1:40	<1.00	1.00	1	N
25-SUS-43-Toilet-TS23-1	Sink	Restroom	N	011608742-0026	EMSL	03036	12/19/2016	200.8	12/30/2016	1:40	3.68	1.00	1	N
26-SUS-19-Principals Toilet-CS7-1	Sink	Principal's Office	N	011608742-0027	EMSL	03036	12/19/2016	200.8	12/30/2016	1:41	5.03	1.00	1	N
27-SUS-17-Nurse-CS5-1	Sink	Nurse's	N	011608742-0028	EMSL	03036	12/19/2016	200.8	12/30/2016	1:42	<1.00	1.00	1	N
28-SUS-20-Toilet-TS9-1	Sink	Restroom	N	011608742-0029	EMSL	03036	12/19/2016	200.8	12/30/2016	1:42	160	5.00	5	N
29-SUS-9-Classroom-CS2-1	Sink	Classroom	N	011608742-0030	EMSL	03036	12/19/2016	200.8	12/30/2016	1:43	11.5	1.00	1	N
30-SUS-24-Toilet-TS13-1	Sink	Restroom	N	011608742-0031	EMSL	03036	12/19/2016	200.8	12/30/2016	1:44	1.24	1.00	1	N
31-SUS-23-Toilet-TS12-1	Sink	Restroom	N	011608742-0032	EMSL	03036	12/19/2016	200.8	12/30/2016	1:47	<1.00	1.00	1	N
32-SUS-22-Toilet-TS11-1	Sink	Restroom	N	011608742-0033	EMSL	03036	12/19/2016	200.8	12/30/2016	1:48	<1.00	1.00	1	N
33-SUS-21-Toilet-TS10-1	Sink	Restroom	N	011608742-0034	EMSL	03036	12/19/2016	200.8	12/30/2016	1:49	<1.00	1.00	1	N
34-SUS-14-Toilet-TS7-1	Sink	Restroom	N	011608742-0035	EMSL	03036	12/19/2016	200.8	12/30/2016	1:49	<1.00	1.00	1	N

35-SUS-13-Toilet-TS6-1	Sink	Restroom	N	011608742-0036	EMSL	03036	12/19/2016	200.8	12/30/2016	1:50	1.96 1.00	1 N
36-SUS-12-Toilet-TS5-1	Sink	Restroom	N	011608742-0037	EMSL	03036	12/19/2016	200.8	12/30/2016	1:51	<1.00 1.00	1 N
37-SUS-50-Classroom-CS16-1	Sink	Classroom	N	011608742-0038	EMSL	03036	12/19/2016	200.8	12/30/2016	1:51	5.39 1.00	1 N
38-SUS-49-Toilet-TS28-1	Sink	Restroom	N	011608742-0039	EMSL	03036	12/19/2016	200.8	12/30/2016	1:52	3.05 1.00	1 N
39-SUS-57-Toilet-TS32-1	Sink	Restroom	N	011608742-0040	EMSL	03036	12/19/2016	200.8	12/30/2016	1:53	1.09 1.00	1 N
40-SUS-56-Toilet-TS31-1	Sink	Restroom	N	011608742-0041	EMSL	03036	12/19/2016	200.8	12/29/2016	22:16	<1.00 1.00	1 N
41-SUS-55-Toilet-TS30-1	Sink	Restroom	N	011608742-0042	EMSL	03036	12/19/2016	200.8	12/29/2016	22:16	4.00 1.00	1 N
42-SUS-54-Toilet-TS29-1	Sink	Restroom	N	011608742-0043	EMSL	03036	12/19/2016	200.8	12/29/2016	22:17	1.67 1.00	1 N
43-SUS-47-Toilet-TS27-1	Sink	Restroom	N	011608742-0044	EMSL	03036	12/19/2016	200.8	12/29/2016	22:18	3.07 1.00	1 N
44-SUS-46-Toilet-TS26-1	Sink	Restroom	N	011608742-0045	EMSL	03036	12/19/2016	200.8	12/29/2016	22:19	<1.00 1.00	1 N
45-SUS-45-Toilet-TS25-1	Sink	Restroom	N	011608742-0046	EMSL	03036	12/19/2016	200.8	12/29/2016	22:19	1.36 1.00	1 N