

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-FIELD BLANK			N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	<1.00	1.00	1	N
1-VMS-1-TOILET-TS1-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.82	1.00	1	N
2-VMS-2-TOILET-TS2-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	1.67	1.00	1	N
3-VMS-3-MECH-TS3-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/21/2016	13.8	1.00	1	N
4-VMS-4-TOILET-TS4-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	199	10.0	10	N
5-VMS-5-TOILET-TS5-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.67	1.00	1	N
6-VMS-6-TOILET-TS6-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	8.17	1.00	1	N
7-VMS-7-GIRLS-TS7-1	Sink	Girls' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.12	1.00	1	N
8-VMS-8-GIRLS-TS8-1	Sink	Girls' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.72	1.00	1	N
9-VMS-9-GIRLS-TS9-1	Sink	Girls' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	1.74	1.00	1	N
10-VMS-12-TOILET-TS11-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.42	1.00	1	N
11-VMS-13-TOILET-TS12-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.33	1.00	1	N
12-VMS-14-TOILET-TS13-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	9.72	1.00	1	N
13-VMS-15-TOILET-TS14-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.64	1.00	1	N
14-VMS-16-NURSE-CS1-1	Sink	Nurse's Office	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	3.13	1.00	1	N
15-VMS-17-BOYS-TS15-1	Sink	Boys' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.91	1.00	1	N
16-VMS-18-BOYS-TS16-1	Sink	Boys' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	3.66	1.00	1	N
17-VMS-20-TOILET-TS18-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.99	1.00	1	N
18-VMS-21-TOILET-TS19-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	1.97	1.00	1	N
19-VMS-22-TOILET-TS20-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	3.64	1.00	1	N
20-VMS-23-TOILET-TS21-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.24	1.00	1	N
21-VMS-25-TOILET-TS22-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	20.1	1.00	1	N
22-VMS-26-TOILET-TS23-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	6.60	1.00	1	N
23-VMS-27-TOILET-TS24-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.04	1.00	1	N
24-VMS-28-TOILET-TS25-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	4.16	1.00	1	N
25-VMS-29-TOILET-TS26-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	6.35	1.00	1	N
26-VMS-30-TOILET-TS27-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	3.34	1.00	1	N
27-VMS-35-BOYS-TS31-1	Sink	Boys' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.51	1.00	1	N
28-VMS-37-TOILET-TS33-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	6.16	1.00	1	N
29-VMS-42-TOILET-TS34-1	Sink	Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	18.4	1.00	1	N
30-VMS-43-GIRLS-TS35-1	Sink	Girls' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	1.13	1.00	1	N
31-VMS-44-GIRLS-TS36-1	Sink	Girls' Restroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.53	1.00	1	N
33-VMS-38-ROOM 4-KS1-1	Sink	Kitchen	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	3.41	1.00	1	N
34-VMS-39-ROOM 4-KS2-1	Sink	Kitchen	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	1.24	1.00	1	N
35-VMS-41-ROOM 5-CS3-1	Sink	Classroom	N	011608663-1	EMSL	03036	12/15/2016	200.8	12/22/2016	2.57	1.00	1	N

36-VMS-40-ROOM 5-CS2-1	Sink	Classroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 4.52	1.00	1 N
37-VMS-46-ANNEX-22-TS38-	Sink	Restroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 <1.00	1.00	1 N
38-VMS-47-ANNEX-23-TS39-	Sink	Restroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 1.73	1.00	1 N
39-VMS-48-ANNEX-24-TS40-	Sink	Restroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 <1.00	1.00	1 N
40-VMS-49-ANNEX-25-TS41-	Sink	Restroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 1.13	1.00	1 N
41-VMS-51-ANNEX-24-C4-1	Sink	Restroom	N	011608663-EMSL	03036	12/15/2016 200.8	12/22/2016 3.03	1.00	1 N