

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Concentration in ug/L	Limit (ug/L)	Dilution Factor	Digested (Y/N)
F1-FIELD BLANK			N	011608788-0001	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
1-WIG1-BOILER-CS1-1	Sink	Boiler Room	N	011608788-0002	EMSL	03036	12/20/2016	200.8	1/3/2017	2.46	1.00	1	N
2-WIG-2-TOILET-TS1-1	Slnk	Restroom	N	011608788-0003	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
3-WIG-5-TOILET-TS2-1	Slnk	Restroom	N	011608788-0004	EMSL	03036	12/20/2016	200.8	1/3/2017	1.97	1.00	1	N
4-WIG-6-CLASS-CS3-1	Sink	Classroom	N	011608788-0005	EMSL	03036	12/20/2016	200.8	1/3/2017	11.1	1.00	1	N
5-WIG-8-CLASS-CS4-1	Sink	Classroom	N	011608788-0006	EMSL	03036	12/20/2016	200.8	1/3/2017	1.95	1.00	1	N
6-WIG-9-CLASS-CS5-1	Sink	Classroom	N	011608788-0007	EMSL	03036	12/20/2016	200.8	1/3/2017	5.35	1.00	1	N
7-WIG-10-CLASS-CS7-1	Sink	Classroom	N	011608788-0008	EMSL	03036	12/20/2016	200.8	1/3/2017	3.76	1.00	1	N
8-WIG-11-CLASS-CS8-1	Sink	Classroom	N	011608788-0009	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
9-WIG-12-CLASS-CS9-1	Sink	Classroom	N	011608788-0010	EMSL	03036	12/20/2016	200.8	1/3/2017	3.46	1.00	1	N
10-WIG-15-TOILET-TS3-1	Slnk	Restroom	N	011608788-0011	EMSL	03036	12/20/2016	200.8	1/3/2017	15.1	1.00	1	N
13-WIG-19-GIRLS-TS6-1	Sink	Girls' Restroom	N	011608788-0014	EMSL	03036	12/20/2016	200.8	1/3/2017	2.52	1.00	1	N
14-WIG-20-GIRLS-TS7-1	Sink	Girls' Restroom	N	011608788-0015	EMSL	03036	12/20/2016	200.8	1/3/2017	2.31	1.00	1	N
15-WIG-21-GIRLS-TS8-1	Sink	Girls' Restroom	N	011608788-0016	EMSL	03036	12/20/2016	200.8	1/3/2017	2.72	1.00	1	N
16-WIG-22-GIRLS-TS9-1	Sink	Girls' Restroom	N	011608788-0017	EMSL	03036	12/20/2016	200.8	1/3/2017	4.47	1.00	1	N
17-WIG-24-BOYS-TS10-1	Sink	Boys' Restroom	N	011608788-0018	EMSL	03036	12/20/2016	200.8	1/3/2017	3.01	1.00	1	N
18-WIG-25-BOYS-TS11-1	Sink	Boys' Restroom	N	011608788-0019	EMSL	03036	12/20/2016	200.8	1/3/2017	2.52	1.00	1	N
19-WIG-26-BOYS-TS12-1	Sink	Boys' Restroom	N	011608788-0020	EMSL	03036	12/20/2016	200.8	1/3/2017	1.55	1.00	1	N
20-WIG-27-CLASS-CS12-1	Sink	Classroom	N	011608788-0021	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
21-WIG-28-TOILET-TS13-1	Sink	Restroom	N	011608788-0022	EMSL	03036	12/20/2016	200.8	1/3/2017	9.95	1.00	1	N
22-WIG-29-CLASS-CS13-1	Sink	Classroom	N	011608788-0023	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
23-WIG-30-TOILET-TS14-1	Sink	Restroom	N	011608788-0024	EMSL	03036	12/20/2016	200.8	1/3/2017	2.46	1.00	1	N
24-WIG-31-CLASS-CS14-1	Sink	Classroom	N	011608788-0025	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
25-WIG-32-TOILET-TS15-1	Sink	Restroom	N	011608788-0026	EMSL	03036	12/20/2016	200.8	1/3/2017	2.99	1.00	1	N
26-WIG-33-CLASS CS15-1	Sink	Classroom	N	011608788-0027	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
27-WIG-34-TOILET-TS16-1	Sink	Restroom	N	011608788-0028	EMSL	03036	12/20/2016	200.8	1/3/2017	1.79	1.00	1	N
28-WIG-35-CLASS-CS16-1	Sink	Classroom	N	011608788-0029	EMSL	03036	12/20/2016	200.8	1/3/2017	1.14	1.00	1	N
30-WIG-37-CLASS-CS17-1	Sink	Classroom	N	011608788-0031	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
31-WIG-38-TOILET-TS18-1	Sink	Restroom	N	011608788-0032	EMSL	03036	12/20/2016	200.8	1/3/2017	2.76	1.00	1	N
32-WIG-39-CLASS-CS18-1	Sink	Classroom	N	011608788-0033	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
33-WIG-40-TOILET-TS19-1	Sink	Restroom	N	011608788-0034	EMSL	03036	12/20/2016	200.8	1/3/2017	1.78	1.00	1	N
34-WIG-41-CLASS-CS19-1	Sink	Classroom	N	011608788-0035	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
35-WIG-42-TOILET-TS20-1	Sink	Restroom	N	011608788-0036	EMSL	03036	12/20/2016	200.8	1/3/2017	1.50	1.00	1	N
36-WIG-43-CLASS-CS20-1	Sink	Classroom	N	011608788-0037	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
38-WIG-45-CLASS-CS21-1	Sink	Classroom	N	011608788-0039	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
40-WIG-47-CLASS-CS22-1	Sink	Classroom	N	011608788-0041	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N

41-WIG-48-TOILET-TS23-1	Sink	Restroom	N	011608788-0042	EMSL	03036	12/20/2016	200.8	1/3/2017	11.9	1.00	1	N
42-WIG-49-CLASS-CS23-1	Sink	Classroom	N	011608788-0043	EMSL	03036	12/20/2016	200.8	1/3/2017	1.35	1.00	1	N
43-WIG-50-TOILET-TS24-1	Sink	Restroom	N	011608788-0044	EMSL	03036	12/20/2016	200.8	1/3/2017	2.12	1.00	1	N
44-WIG-51-CLASS-CS24-1	Sink	Classroom	N	011608788-0045	EMSL	03036	12/20/2016	200.8	1/3/2017	4.74	1.00	1	N
45-WIG-52-CLASS-CS25-1	Sink	Classroom	N	011608788-0046	EMSL	03036	12/20/2016	200.8	1/3/2017	7.83	1.00	1	N
46-WIG-53-CLASS-CS26-1	Sink	Classroom	N	011608788-0047	EMSL	03036	12/20/2016	200.8	1/3/2017	2.98	1.00	1	N
47-WIG-55-CLASS-CS28-1	Sink	Classroom	N	011608788-0048	EMSL	03036	12/20/2016	200.8	1/3/2017	3.23	1.00	1	N
48-WIG-56-WOMEN-TS25-1	Sink	Women's Restroom	N	011608788-0049	EMSL	03036	12/20/2016	200.8	1/3/2017	3.46	1.00	1	N
49-WIG-57-MEN-TS26-1	Sink	Men's Restroom	N	011608788-0050	EMSL	03036	12/20/2016	200.8	1/3/2017	3.67	1.00	1	N
50-WIG-54-CLASS-CS27-1	Sink	Classroom	N	011608788-0051	EMSL	03036	12/20/2016	200.8	1/3/2017	2.96	1.00	1	N
51-WIG-58-CLASS-CS29-1	Sink	Classroom	N	011608788-0052	EMSL	03036	12/20/2016	200.8	1/3/2017	5.88	1.00	1	N
52-WIG-60-GIRLS-TS27-1	Sink	Girls' Restroom	N	011608788-0053	EMSL	03036	12/20/2016	200.8	1/3/2017	4.85	1.00	1	N
53-WIG-61-GIRLS-TS28-1	Sink	Girls' Restroom	N	011608788-0054	EMSL	03036	12/20/2016	200.8	1/3/2017	1.32	1.00	1	N
54-WIG-62-GIRLS-TS29-1	Sink	Girls' Restroom	N	011608788-0055	EMSL	03036	12/20/2016	200.8	1/3/2017	1.10	1.00	1	N
55-WIG-63-GIRLS-TS30-1	Sink	Girls' Restroom	N	011608788-0056	EMSL	03036	12/20/2016	200.8	1/3/2017	1.34	1.00	1	N
56-WIG-64-GIRLS-TS31-1	Sink	Girls' Restroom	N	011608788-0057	EMSL	03036	12/20/2016	200.8	1/3/2017	3.25	1.00	1	N
57-WIG-65-BOYS-TS32-1	Sink	Boys' Restroom	N	011608788-0058	EMSL	03036	12/20/2016	200.8	1/3/2017	11.3	1.00	1	N
58-WIG-66-BOYS-TS33-1	Sink	Boys' Restroom	N	011608788-0059	EMSL	03036	12/20/2016	200.8	1/3/2017	1.44	1.00	1	N
59-WIG-67-BOYS-TS34-1	Sink	Boys' Restroom	N	011608788-0060	EMSL	03036	12/20/2016	200.8	1/3/2017	3.82	1.00	1	N
60-WIG-68-BOYS-TS35-1	Sink	Boys' Restroom	N	011608788-0061	EMSL	03036	12/20/2016	200.8	1/3/2017	1.95	1.00	1	N
61-WIG-69-BOYS-TS36-1	Sink	Boys' Restroom	N	011608788-0062	EMSL	03036	12/20/2016	200.8	1/3/2017	1.51	1.00	1	N
62-WIG-71-CLASS-CS31-1	Sink	Classroom	N	011608788-0063	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
63-WIG-70-CLASS-CS30-1	Sink	Classroom	N	011608788-0064	EMSL	03036	12/20/2016	200.8	1/3/2017	1.99	1.00	1	N
64-WIG-72-CLASS-CS32-1	Sink	Classroom	N	011608788-0065	EMSL	03036	12/20/2016	200.8	1/3/2017	1.88	1.00	1	N
65-WIG-73-CLASS-CS33-1	Sink	Classroom	N	011608788-0066	EMSL	03036	12/20/2016	200.8	1/3/2017	1.38	1.00	1	N
66-WIG-74-CLASS-CS34-1	Sink	Classroom	N	011608788-0067	EMSL	03036	12/20/2016	200.8	1/3/2017	2.72	1.00	1	N
67-WIG-75-CLASS-CS35-1	Sink	Classroom	N	011608788-0068	EMSL	03036	12/20/2016	200.8	1/3/2017	1.56	1.00	1	N
68-WIG-76-CLASS-CS36-1	Sink	Classroom	N	011608788-0069	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
69-WIG-77-CLASS-CS37-1	Sink	Classroom	N	011608788-0070	EMSL	03036	12/20/2016	200.8	1/3/2017	1.26	1.00	1	N
70-WIG-78-CLASS-CS38-1	Sink	Classroom	N	011608788-0071	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
71-WIG-79-CLASS-CS39-1	Sink	Classroom	N	011608788-0072	EMSL	03036	12/20/2016	200.8	1/3/2017	1.55	1.00	1	N
73-WIG-81-CLASS-CS41-1	Sink	Classroom	N	011608788-0074	EMSL	03036	12/20/2016	200.8	1/3/2017	3.08	1.00	1	N
74-WIG-82-CLASS-CS42-1	Sink	Classroom	N	011608788-0075	EMSL	03036	12/20/2016	200.8	1/3/2017	2.06	1.00	1	N
75-WIG-83-TOILET-TS37-1	Sink	Classroom	N	011608788-0076	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
11-WIG-16-TOILET-TS4-1	Sink	Restroom	N	011608788-0012	EMSL	03036	12/20/2016	200.8	1/3/2017	28.7	1.00	1	N
12-WIG-18-TOILET-TS5-1	Sink	Restroom	N	011608788-0013	EMSL	03036	12/20/2016	200.8	1/3/2017	59.1	1.00	1	N
29-WIG-36-TOILET-TS17-1	Sink	Restroom	N	011608788-0030	EMSL	03036	12/20/2016	200.8	1/3/2017	23.5	1.00	1	N
37-WIG-44-TOILET-TS21-1	Sink	Restroom	N	011608788-0038	EMSL	03036	12/20/2016	200.8	1/3/2017	24.4	1.00	1	N

39-WIG-46-TOILET-TS22-1	Sink	Restroom	N	011608788-0040	EMSL	03036	12/20/2016	200.8	1/3/2017	24.9	1.00	1	N
72-WIG-80-CLASS-CS40-1	Sink	Classroom	N	011608788-0073	EMSL	03036	12/20/2016	200.8	1/3/2017	21.9	1.00	1	N