

Field ID	Type	Location	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Analytical Method	Date of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)
FB-FIELD BLANK			N	011608787-0001	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
1-YRK-59-LOUNGE-CS12-1	Sink	Classroom	N	011608787-0002	EMSL	03036	12/20/2016	200.8	1/3/2017	3.04	1.00	1	N
2-YRK-1-PRE K-CSB1-1	Sink w/ Bubbler	Classroom	N	011608787-0003	EMSL	03036	12/20/2016	200.8	1/3/2017	1.09	1.00	1	N
3-YRK-1B-PRE K-CSB1-1	Sink w/ Bubbler	Classroom	N	011608787-0004	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
4-YRK-2-PRE K-TS2-1	Sink	Classroom	N	011608787-0005	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
5-YRK-3-PRE K-CSB2-1	Sink w/ Bubbler	Classroom	N	011608787-0006	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
6-YRK-3B-PRE K-CSB2-1	Sink w/ Bubbler	Classroom	N	011608787-0007	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
7-YRK-4-TOILET-TS1-1	Sink	Restroom	N	011608787-0008	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
8-YRK-5-GIRLS-TS3-1	Sink	Boy	N	011608787-0009	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
9-YRK-6-GIRLS-TS4-1	Sink	Girls' Restroom	N	011608787-0010	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
10-YRK-7-GIRLS-TS5-1	Sink	Girls' Restroom	N	011608787-0011	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
11-YRK-8-GIRLS-TS6-1	Sink	Girls' Restroom	N	011608787-0012	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
12-YRK-9-BOYS-TS7-1	Sink	Boys' Restroom	N	011608787-0013	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
13-YRK-10-BOYS-TS8-1	Sink	Boys' Restroom	N	011608787-0014	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
14-YRK-11-BOYS-TS9-1	Sink	Boys' Restroom	N	011608787-0015	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
15-YRK-13-PRE K-CSB3-1	Sink w/ Bubbler	Classroom	N	011608787-0016	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
16-YRK-14-TOILET-TS10-1	Sink	Restroom	N	011608787-0017	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
17-YRK-16-NURSE-TS12-1	Sink	Nurse's Office	N	011608787-0018	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
18-YRK-17-KITCHEN-KS1-1	Sink	Kitchen	N	011608787-0019	EMSL	03036	12/20/2016	200.8	1/3/2017	1.00	1.00	1	N
19-YRK-18-KITCHEN-KS2-1	Sink	Kitchen	N	011608787-0020	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
20-YRK-20-TOILET-TS13-1	Sink	Restroom	N	011608787-0021	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
21-YRK-21-TOILET-TS14-1	Sink	Restroom	N	011608787-0022	EMSL	03036	12/20/2016	200.8	1/3/2017	3.62	1.00	1	N
22-YRK-23-BOYS-TS15-1	Sink	Boys' Restroom	N	011608787-0023	EMSL	03036	12/20/2016	200.8	1/3/2017	1.26	1.00	1	N
23-YRK-24-BOYS-TS16-1	Sink	Boys' Restroom	N	011608787-0024	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
24-YRK-25-BOYS-TS17-1	Sink	Boys' Restroom	N	011608787-0025	EMSL	03036	12/20/2016	200.8	1/3/2017	1.07	1.00	1	N
25-YRK-26-TOILET-TS18-1	Sink	Restroom	N	011608787-0026	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
26-YRK-28-GIRLS-TS19-1	Sink	Girls' Restroom	N	011608787-0027	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
27-YRK-29-GIRLS-TS20-1	Sink	Girls' Restroom	N	011608787-0028	EMSL	03036	12/20/2016	200.8	1/3/2017	1.37	1.00	1	N
28-YRK-30-GIRLS-TS21-1	Sink	Girls' Restroom	N	011608787-0029	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
29-YRK-31-TOILET-TS22-1	Sink	Restroom	N	011608787-0030	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1	N
30-YRK-32-T.TOILET-TS23-1	Sink	Restroom	N	011608787-0031	EMSL	03036	12/20/2016	200.8	1/3/2017	1.93	1.00	1	N
31-YRK-33-T.TOILET-TS24-1	Sink	Restroom	N	011608787-0032	EMSL	03036	12/20/2016	200.8	1/3/2017	2.63	1.00	1	N
32-YRK-34-T.TOILET-TS25-1	Sink	Restroom	N	011608787-0033	EMSL	03036	12/20/2016	200.8	1/3/2017	3.43	1.00	1	N
33-YRK-35-SCIENCE-CS4-1	Sink	Classroom	N	011608787-0034	EMSL	03036	12/20/2016	200.8	1/3/2017	39.3	1.00	1	N
34-YRK-36-SCIENCE-CS5-1	Sink	Classroom	N	011608787-0035	EMSL	03036	12/20/2016	200.8	1/3/2017	2.66	1.00	1	N
35-YRK-38-ART-CS7-1	Sink	Classroom	N	011608787-0036	EMSL	03036	12/20/2016	200.8	1/3/2017	12.2	1.00	1	N
36-YRK-39-ART-CS8-1	Sink	Classroom	N	011608787-0037	EMSL	03036	12/20/2016	200.8	1/3/2017	88.0	1.00	1	N

37-YRK-40-ART-CS9-1	Sink	Classroom	N	011608787-0038	EMSL	03036	12/20/2016	200.8	1/3/2017	6.33	1.00	1 N
38-YRK-41-ART-C10-1	Sink	Classroom	N	011608787-0039	EMSL	03036	12/20/2016	200.8	1/3/2017	3.41	1.00	1 N
39-YRK-42-GIRLS-TS27-1	Sink	Girls' Restroom	N	011608787-0040	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
40-YRK-43-GIRLS-TS28-1	Sink	Girls' Restroom	N	011608787-0041	EMSL	03036	12/20/2016	200.8	1/3/2017	1.11	1.00	1 N
41-YRK-44-GIRLS-TS29-1	Sink	Girls' Restroom	N	011608787-0042	EMSL	03036	12/20/2016	200.8	1/3/2017	1.29	1.00	1 N
42-YRK-45-GIRLS-TS30-1	Sink	Girls' Restroom	N	011608787-0043	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
43-YRK-46-BOYS-TS31-1	Sink	Boys' Restroom	N	011608787-0044	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
44-YRK-47-BOYS-TS32-1	Sink	Boys' Restroom	N	011608787-0045	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
45-YRK-48-BOYS-TS33-1	Sink	Boys' Restroom	N	011608787-0046	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
46-YRK-51-MENS-TS34-1	Sink	Mens' Restroom	N	011608787-0047	EMSL	03036	12/20/2016	200.8	1/3/2017	16.2	1.00	1 N
		Womens'										
47-YRK-52-WOMEN-TS35-1	Sink	Restroom	N	011608787-0048	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
48-YRK-53-BOYS-TS36-1	Sink	Boys' Restroom	N	011608787-0049	EMSL	03036	12/20/2016	200.8	1/3/2017	6.50	1.00	1 N
49-YRK-54-BOYS-TS37-1	Sink	Boys' Restroom	N	011608787-0050	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N
50-YRK-55-OFFICE-CS11-1	Sink	Classroom	N	011608787-0051	EMSL	03036	12/20/2016	200.8	1/3/2017	6.30	1.00	1 N
51-YRK-57-GIRLS-TS38-1	Sink	Girls' Restroom	N	011608787-0052	EMSL	03036	12/20/2016	200.8	1/3/2017	1.26	1.00	1 N
52-YRK-58-GIRLS-TS39-1	Sink	Girls' Restroom	N	011608787-0053	EMSL	03036	12/20/2016	200.8	1/3/2017	<1.00	1.00	1 N